

BUILDING DIVISION-BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

PERMIT NO. <i>B-33094</i>	LOCATION <i>3920 - 2nd Ave</i>
DATE <i>July 19-51</i>	PURPOSE <i>Add to rear dwlg.</i>
ZONE	OWNER <i>C. Penna</i>
	ARCH'T.
	CONTR. <i>Owner</i>

VAL. <i>9000</i>	STORIES	ROOMS	APTS.	SIZE
------------------	---------	-------	-------	------

LIGHT SHAFTS		ELEVATOR SHAFTS	
VENT SHAFTS		BOILER ROOMS	
OWNER'S INSPECTOR		SPRINKLER SYSTEM	
LATH		GAS VENTS	
FIRE ESCAPES		CHIMNEYS	
STAND PIPES		SKYLIGHTS	

DATE	CONDITION OF WORK—REMARKS
7-23-51	<i>Frames</i> <i>R.C. Control</i>
8/6/51	Frame Insp. (Stocco wire to be double 20 Ga. & Kick blocks to be installed) (E.B.)

COMPLETE
AND O. K.

INSPECTOR