CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0405837
Insp Area: 4
Thos Bros: 277E7

Site Address: 5408 GARDEN HY SAC
Parcel No: 274-0110-010 BUILDING B

Sub-Type: NCOM
Housing (Y/N): N

CONTRACTOR
K-BAR CONSTRUCTION INC.
1757 BASELINE ROAD, STE 142
GILBERT, AZ 85233

OWNER
SCHOMAC GROUP INC
5408 GARDEN HY
SACRAMENTO CA 95837

ARCHITECT
ARCHICON LC
4041 N CENTRAL AVE #C-100
PHOENIX AZ 85012

Nature of Work: BUILDING B 39,012 sf SELF STORAGE.

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name_____ Lender'sAddress_____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 770791 Date 5-12-05 Contractor Signature [signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars ($500.00);

_____ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

_____ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

PAID
CITY OF SACRAMENTO
MAY 12 2005
NORTH PERMIT CENTER

_____ I am exempt under Sec._____ B & PC for this reason:_____

Date_____ Owner Signature_____

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 5-12-05 Applicant/Agent Signature [signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:
_____ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

_____ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier Policy Number Exp Date

X (This section need not be completed if the permit is for $100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 5-12-05 Applicant Signature [signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS ($100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

CLARK HEATING & AIR CONDITIONING

Contractor License #808427

SYSTEM SURVEY

9341 Greenback LN. Orangevale, CA. 95662 (916) 988-1658 (916) 988-1992

February 2ND, 2007

C6031 "BUILDING B" AIR BALANCE REPORT

NATIONAL SELF STORAGE
5408 GARDEN HIGHWAY
SACRAMENTO, CA.

GENERAL CONTRACTOR: KBAR CONSTRUCTION

MECHANICAL CONTRACTOR: CLARK HEATING & AIR CONDITIONING

ARCHITECH: ARCHITECHTURE & INTERIORS

TEST PERFORMED BY: MICHAEL BAKER

Permit #0405837

Clark Air Conditioning & Heating
Po Box 368
Orangevale, Ca 95662 Lic #808427

Job No. C6031

Section | Page 1

Fan Outlet Test Data

Date 2/2/2007

K-Bar Construction — National Self Storage, Garden Hwy, Sac

Unit Bldg B IU-B1

Area Served: Bldg B 1st Floor

Motor Name Plate Data		Data Item	Design	Test 1	Test 2				
MFG	Trane	Volts	208						
Hp	1	Amps	n/a						
PH	1	BHP	n/a						
Sheave Data		RPM	n/a						
Dia	Shaft	SP-	1"						
Adj %	Fixed	Sp+	1"						
Fan Name Plate Data		Tsp/Esp							
Mfg		Filter sp	.75						
Model		CFM Total	2000	1460	1820				
Type		CFM RA	1660	1250	1530				
Size		CFM OA min	340	210	290				
Sheave Data		CFM	2000	1460	1820				
Dia	Shaft								
Belts									

	Fan Submittal Data			Design		Test 1		Test 2		Test 3	
Room	Opening		Factor	FPM	CFM	FPM	CFM	FMP	CFM	FMP	CFM
Hall	No. Type	Size									
#1	mod.	12x12	1	NA	500	580	417	630	470		
#2	"	12x12	1		500	540	388	615	450		
#3	"	12x12	1		500	450	324	610	440		
#4	"	12x12	1		500	460	331	620	460		

Remarks:

Clark Air Conditioning & Heating
Po Box 368
Orangevale, Ca 95662 Lic #808427

Job No. C6031

Section | Page 1

Fan Outlet Test Data

Date 2/2/2007

K-Bar Construction National Self Storage
Garden Hwy, Sac

Unit Bldg B IU-B2

Area Served Bldg B 1st Floor

Motor Name Plate Data		Data Item	Design	Test 1	Test 2				
MFG	Trane	Volts	208						
Hp	1	Amps	n/a						
PH	1	BHP	n/a						
Sheave Data		RPM	n/a						
Dia	Shaft	SP-	1"						
Adj %	Fixed	Sp+	1"						
Fan Name Plate Data		Tsp/Esp							
Mfg		Filter sp	.75						
Model		CFM Total	2000	1538	1580				
Type		CFM RA	1660	220	310				
Size		CFM OA min	340	1758	1890				
Sheave Data		CFM	2000						
Dia	Shaft								
Belts									

	Fan Submittal Data			Design		Test 1		Test 2		Test 3	
Room	Opening		Factor	FPM	CFM	FPM	CFM	FMP	CFM	FMP	CFM
Hall	No. Type	Size									
#1	mod.	12x12	1	NA	270	490	352	410	260		
#2	"	8x8	1		165	390	234	200	140		
#3	"	8x8	1		50	360	216	170	90		
#4	"	9x9	1		270	430	172	440	255		
#5	"	9x9	1		270	420	168	450	258		
#6	"	9x9	1		270	400	160	420	240		
#7	"	9x9	1		270	410	164	420	240		
#8	"	9x9	1		270	380	152	400	220		
#9	"	9x9	1		270	350	140	398	207		

Remarks:

Clark Air Conditioning & Heating
Po Box 368
Orangevale, Ca 95662 Lic #808427

Job No. C6031

Section | Page 1

Fan Outlet Test Data

Date 2/2/2007

K-Bar Construction National Self Storage
Garden Hwy, Sac

Unit Bldg B IU-B3

Area Served Bldg B 1st Floor

Motor Name Plate Data		Data Item	Design	Test 1	Test 2				
MFG	Trane	Volts	208						
Hp	1	Amps	n/a						
PH	1	BHP	n/a						
Sheave Data		RPM	n/a						
Dia	Shaft	SP-	1"						
Adj %	Fixed	Sp+	1"						
Fan Name Plate Data		Tsp/Esp							
Mfg		Filter sp	.75						
Model		CFM Total	2000	1180	1302				
Type		CFM RA	1660	180	280				
Size		CFM OA min	340	1360	1582				
Sheave Data		CFM	2000						
Dia	Shaft								
Belts									

	Fan Submittal Data			Design		Test 1		Test 2		Test 3	
Room	Opening		Factor	FPM	CFM	FPM	CFM	FMP	CFM	FMP	CFM
Hall	No. Type	Size									
#1	mod.	9x9	1	NA	220	440	176	495	190		
#2	"	9x9	1		220	470	188	500	198		
#3	"	9x9	1		220	435	174	501	198		
#4	"	9x9	1		220	490	196	520	210		
#5	"	9x9	1		220	480	192	520	210		
#6	"	9x9	1		220	395	158	500	198		
#7	"	9x9	1		220	370	148	500	198		
#8	"	9x9	1		220	320	128	485	180		

Remarks:

Clark Air Conditioning & Heating
Po Box 368
Orangevale, Ca 95662 Lic #808427

Job No. C8031

Section | Page 1

Fan Outlet Test Data

Date 2/2/2007

K-Bar Construction National Self Storage
Garden Hwy, Sac

Unit Bldg B IU-B5

Area Served Bldg B 1st Floor

Motor Name Plate Data		Data Item	Design	Test 1	Test 2				
MFG	Trane	Volts	208						
Hp	1	Amps	n/a						
PH	1	BHP	n/a						
Sheave Data		RPM	n/a						
Dia	Shaft	SP-	1"						
Adj %	Fixed	Sp+	1"						
Fan Name Plate Data		Tsp/Esp							
Mfg		Filter sp	.75						
Model		CFM Total	2000	1420	1417				
Type		CFM RA	1660	280	283				
Size		CFM OA min	340	1700	1700				
Sheave Data		CFM	2000						
Dia	Shaft								
Belts									

	Fan Submittal Data			Design		Test 1		Test 2		Test 3	
Room	Opening		Factor	FPM	CFM	FPM	CFM	FMP	CFM	FMP	CFM
Hall	No. Type	Size									
#1	mod.	12x12	1	NA	330	570	410	490	320		
#2	"	12x12	1		330	562	404	485	315		
#3	"	12x12	1		330	515	370	480	305		
#4	"	9x9	1		200	478	191	475	190		
#5	"	9x9	1		200	420	168	475	190		
#6	"	9x9	1		200	430	172	475	190		
#7	"	9x9	1		200	411	164	465	190		

Remarks:

Clark Air Conditioning & Heating
Po Box 368
Orangevale, Ca 95662 Lic #808427

Job No. C6031

Section | Page 1

Fan Outlet Test Data

Date 2/2/2007

K-Bar Construction National Self Storage
Garden Hwy, Sac

Unit Bldg B IU-B6

Area Served	Bldg B 1st Floor									
Motor Name Plate Data			Data Item	Design	Test 1	Test 2				
MFG	Trane		Volts	208						
Hp	1		Amps	n/a						
PH	1		BHP	n/a						
Sheave Data			RPM	n/a						
Dia	Shaft		SP-	1"						
Adj %	Fixed		Sp+	1"						
Fan Name Plate Data			Tsp/Esp							
Mfg			Filter sp	.75						
Model			CFM Total	2000	1516	1523				
Type			CFM RA	1660	310	302				
Size			CFM OA min	340	1825	1825				
Sheave Data			CFM	2000						
Dia	Shaft									
Belts										

	Fan Submittal Data			Design		Test 1		Test 2		Test 3	
Room	Opening		Factor	FPM	CFM	FPM	CFM	FMP	CFM	FMP	CFM
Hall	No. Type	Size									
#1	mod.	12x12	1	NA	500	636	457	640	460		
#2	"	12x12	1		500	653	470	640	460		
#3	"	12x12	1		500	555	399	620	450		
#4	"	12x12	1		500	542	390	625	455		

Remarks:

Clark Air Conditioning & Heating
Po Box 368
Orangevale, Ca 95662 Lic #808427

Job No. C6031

Section | Page 1

Fan Outlet Test Data

Date 2/2/2007

K-Bar Construction — National Self Storage, Garden Hwy, Sac

Unit Bldg B IU-B7

Area Served	Bldg B 1st Floor
Motor Name Plate Data	
MFG	Trane
Hp	1
PH	1
Sheave Data	
Dia	Shaft
Adj %	Fixed
Fan Name Plate Data	
Mfg	
Model	
Type	
Size	
Sheave Data	
Dia	Shaft
Belts	

Data Item	Design	Test 1	Test 2				
Volts	208						
Amps	n/a						
BHP	n/a						
RPM	n/a						
SP-	1"						
Sp+	1"						
Tsp/Esp							
Filter sp	.75						
CFM Total	2000	1512	1510				
CFM RA	1660	290	300				
CFM OA min	340	1802	1810				
CFM	2000						

	Fan Submittal Data			Design		Test 1		Test 2		Test 3	
Room	Opening		Factor	FPM	CFM	FPM	CFM	FMP	CFM	FMP	CFM
Hall	No. Type	Size									
#1	mod.	12x12	1	NA	500	635	457	630	450		
#2	"	12x12	1		500	660	475	650	460		
#3	"	12x12	1		500	640	460	650	460		
#4	"	12x12	1		500	570	410	620	440		

Remarks:

Clark Air Conditioning & Heating
Po Box 368
Orangevale, Ca 95662 Lic #808427

Job No. C6031

Section | Page 1

Fan Outlet Test Data

Date 2/2/2007

K-Bar Construction National Self Storage
Garden Hwy, Sac

Unit Bldg B IU-B6

Area Served	Bldg B 1st Floor									
Motor Name Plate Data			Data Item	Design	Test 1	Test 2				
MFG	Trane		Volts	208						
Hp	1		Amps	n/a						
PH	1		BHP	n/a						
Sheave Data			RPM	n/a						
Dia	Shaft		SP-	1"						
Adj %	Fixed		Sp+	1"						
Fan Name Plate Data			Tsp/Esp							
Mfg			Filter sp	.75						
Model			CFM Total	2000						
Type			CFM RA	1660	1251	1586				
Size			CFM OA min	340	270	321				
Sheave Data			CFM	2000	1521	1907				
Dia	Shaft									
Belts										

	Fan Submittal Data			Design		Test 1		Test 2		Test 3	
Room	Opening		Factor	FPM	CFM	FPM	CFM	FMP	CFM	FMP	CFM
Hall	No. Type	Size									
#1	mod.	9x9	1	NA	330	340	136	405	295		
#2	"	9x9	1		330	375	150	420	310		
#3	"	12x12	1		330	560	403	490	352		
#4	"	12x12	1		330	490	352	490	350		
#6	"	9x9	1		330	680	272	420	300		
#7	"	9x9	1		330	520	208	415	300		

Remarks:

Clark Air Conditioning & Heating
Po Box 368
Orangevale, Ca 95662 Lic #808427

Job No. C6031

Section | Page 1

Fan Outlet Test Data

Date 2/2/2007

K-Bar Construction National Self Storage
Garden Hwy, Sac

Unit Bldg B IU-B9

Area Served Bldg B 1st Floor

Motor Name Plate Data		Data Item	Design	Test 1	Test 2				
MFG	Trane	Volts	208						
Hp	1	Amps	n/a						
PH	1	BHP	n/a						
Sheave Data		RPM	n/a						
Dia	Shaft	SP-	1"						
Adj %	Fixed	Sp+	1"						
Fan Name Plate Data		Tsp/Esp							
Mfg		Filter sp	.75						
Model		CFM Total	2000	1041	1490				
Type		CFM RA	1660	180	250				
Size		CFM OA min	340	1221	1740				
Sheave Data		CFM	2000						
Dia	Shaft								
Belts									

	Fan Submittal Data			Design		Test 1		Test 2		Test 3	
Room	Opening		Factor	FPM	CFM	FPM	CFM	FMP	CFM	FMP	CFM
Hall	No. Type	Size									
#1	mod.	9x9	1	NA	220	490	196	490	200		
#2	"	9x9	1		220	470	188	490	210		
#3	"	9x9	1		220	240	96	480	200		
#4	"	9x9	1		220	240	96	475	190		
#5	"	9x9	1		220	232	92	475	185		
#6	"	9x9	1		220	224	89	470	195		
#7	"	9x9	1		220	420	168	480	200		
#8	"	9x9	1		220	340	136	460	180		
#9	"	9x9	1		220	400	160	460	180		

Remarks: