

**CITY OF SACRAMENTO**  
1231 I Street, Sacramento, CA 95814

**Permit No: 0316525**

**Insp Area: 2**  
**Thos Bros: 317 C1**

**Site Address: 1735 11TH AV SAC**  
**Parcel No: 012-0374-016**

**Sub-Type: ASFR**  
**Housing (Y/N): N**

CONTRACTOR  
UNIQUE CONSTRUCTION  
PO BOX 189188  
SACRAMENTO, CA 95818

OWNER  
JANET OTTERMAN  
1735 11TH AVE  
SACRAMENTO, CA 95818

ARCHITECT

**Nature of Work: 430 SQ FT MSTR BDRM/ BATH ADDN TO SFR**

**CONSTRUCTION LENDING AGENCY :** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_

**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 422037 Date 12-2-03 Contractor Signature [Signature]

**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_  
Date 12-2-03 Owner Signature [Signature]

**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date \_\_\_\_\_ Applicant/Agent Signature \_\_\_\_\_

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier NO EMPLOYEES Policy Number \_\_\_\_\_ Exp Date \_\_\_\_\_

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 12-2-03 Applicant Signature [Signature]

**WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.**

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

City of Sacramento Planning Division  
**PLANNING REVIEW FOR BUILDING PERMIT SUBMITTAL**

ADDRESS: 1735 11 <sup>th</sup> Avenue	APN: 012-0374-016
DRPB AREA / PUD / SPD: None	ZONING: R1
EXISTING LAND USE: One-story single family home with detached garage.	
PROPOSED USE: Add 420 sq. ft. additional living area at back of house, and enlarge concrete patio (not a covered patio).	
<p><b>PLANNING STAFF WILL CHECK ONE OR MORE OF THE ITEMS BELOW:</b></p> <p><input type="checkbox"/> Planning review is NOT required.</p> <p><input type="checkbox"/> Use is NOT allowed; applicant CANNOT submit for plan check.</p> <p><input type="checkbox"/> Requires APPLICATION(s):    PC            ZA            IR            ER            DR            PB</p> <p>Required Planning application must be submitted <i>before</i> project can be submitted for plan check.</p> <p><input type="checkbox"/> Application(s) IN PROGRESS:</p> <p>Applicant may submit for concurrent building permit plan check, at applicant's risk.          Building Division must check with Planning staff and/or SITE before issuing building permit.</p> <p><input type="checkbox"/> Application(s) COMPLETED:</p> <p>Building permit must conform to approved plans and comply with all conditions of approval.          Do NOT issue building permit prior to end of 10 day appeal period.</p> <p><input type="checkbox"/> Plans may be submitted for plan check. Plan checker(s) shall confirm compliance with Zoning Ordinance requirements and all applicable development standards <i>prior to issuance</i> of building permit.</p> <p><input type="checkbox"/> Meets setback &amp; lot coverage requirements as shown on site plan provided.</p> <p><input type="checkbox"/> Site plan to be submitted has been stamped/signed by Planning counter staff.</p> <p><input type="checkbox"/> Route to SITE for plan check and inspection.</p> <p><input type="checkbox"/> Preliminary review ONLY; the information on this form <b>must be reviewed again and confirmed</b> at the time of building permit submittal.</p>	
<p>COMMENTS: Yesterday I approved this site plan, but that was in error. The minimum side yard setback for addition is 3'. The plan scales to less than 3'. At less than 3', a planning entitlement is required and there would be building code issues as well. If the setback is actually at least 3', that setback must be depicted correctly on plans. M.May 10/23/03</p> <p style="text-align: right; font-size: 1.2em;">3' MIN. PER PLANS O.K. BJM</p>	
DATE:	BY: Monica May

CITY OF SACRAMENTO  
 PERMIT ASSISTANCE  
 OCT 23 2003  
**RECEIVED**

GREENBAUM  
& ASSOCIATES  
ARCHITECTS

---

March 8, 2004

City of Sacramento  
Building Inspection Division

Re: Otterman House, 1735 11th Ave., Sacramento, CA

I have inspected the framing as installed. The vaulted ceiling over the bedroom should be omitted, as built, with 2x8 rafters, 2x6 ceiling joists and a 2x10 ridge. The header over the french doors should be a 4x12 with 4x4 at each site of the door.

Please feel free to call our office if you have any questions.

Sincerely,



Dennis Greenbaum

