

BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD

TYPE VII BUILDINGS

PERMIT NO. 2756	LOCATION		
PURPOSE	ROOMS	APTS.	
OWNER	PHONE		
ARCHT			
ENGINEER			
VAL.	STORIES	SIZE	

1578 Q

ISSUED
 DATE MAY 23 1928
 ZONE SACRAMENTO
 BUILDING DIVISION

FOUNDATION	STORY	BSMT	STORIES			ROOF			Cement Tests
			1	2	3				
Ex Wall	Jolsts						Chimneys		
	Beams and Girders						Fire Place		
Int Wall	Studs and Columns						Gas Water Heater		
	Bridging Fire Stops						Heater Closet		
Piers	Fire Escape Stand Pipes						Furnace		Window Courts
	Metal Lath						Boiler Room		
	Stairs						Elevator Shaft		

350 -

DATE

CONDITION OF WORK—REMARKS

5/29/28

3rd INSPECTION. EXT. PATH NOT TAPPED OR NAILED CORRECTLY

A.W. Campbell ✓

5/31/28

3rd INSPECTION. PLASTER APPLIED BY NAIL 3" STRIPS OVER ✓

EXT. 18 GAUGE 1/2" NAIL. SAME AS BEFORE. O.K.

Working with the understanding of A.W. Campbell

COMPLETED
AND O. K.

INSPECTOR