

CITY OF SACRAMENTO  
1231 I Street, Sacramento, CA 95814

Permit No: 0313364

Insp Area: 2  
Thos Bros: 338 A4

Site Address: 6051 MACK RD SAC St: MAXS  
Parcel No: 118-0103-009 # D

Sub-Type: REM  
Housing (Y/N): N

CONTRACTOR  
FOCUS CONSTRUCTION CO  
1852 S MANHATTAN PL  
LOS ANGELES, CA 90019

OWNER  
RAMON SARPOSANTOS / STEVE GO  
8231 WOODMAN AVE  
PANORAMA CITY CA 91402

ARCHITECT

Nature of Work: REMODEL - NEW RESTAURANT

**CONSTRUCTION LENDING AGENCY :** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_

**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class CB License Number 664521 Date MAR 17 1990 Contractor Signature [Signature]

**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

\_\_\_\_ I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

\_\_\_\_ I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

\_\_\_\_ I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_  
Date \_\_\_\_\_ Owner Signature \_\_\_\_\_

PAID  
CITY OF SACRAMENTO  
MAR 17 2004  
NORTH PERM CENTER

**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the above mentioned property for inspection purposes.

Date MAR 17 2004 Applicant/Agent Signature [Signature]

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:

\_\_\_\_ I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

\_\_\_\_ I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE COMPENSATION INS FUND Policy Number 1510673 Exp Date 06/01/2004

\_\_\_\_ (This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date MAR 17 2004 Applicant Signature [Signature]

**WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.**

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

# CIRCO System Balance, Inc.

SB JOB# \_\_\_\_\_  
 SECTION \_\_\_\_\_ PAGE \_\_\_\_\_  
 DATE 6-1-09

## FAN & OUTLET TEST SHEET WITH POWER EXHAUST

REA SERVED KITCHEN HOOD MAKE-UP MAN'S UNIT EC-1

**MC MOTOR NAMEPLATE DATA**

MFG MALATHON FR 56-70  
 HP 1 V 208 FLA 6.4  
 PH 1 SF 115 RPM 1725

**SH SHAFT DATA:**

DIA 1 1/2 SHAFT 3/8  
 ADJ % MID FIXED \_\_\_\_\_

**FA NAMEPLATE DATA**

MFG CHAMPION  
 MODEL # 8500 SD  
 TYPE \_\_\_\_\_  
 SIZE \_\_\_\_\_

**SH SHAFT DATA:**

DIA AK 1 1/2 SHAFT 1"  
 BELTS (1) 4L840

DATA	TEST 1	TEST 2	ECON. MODE
VOLTS	210		
AMPS	6.0		
B.H.P.	.93		
ROOM PRES.			
R.P.M.	413		
S.P. -	.11		
S.P. +	.24		
T.S.P.	.35		
FILTER S.P.	.11		
CFM TOTAL	6007		
CFM R.A.			---
CFM O.A.	100%		100%
CFM P.E.			

**FA DESIGN DATA**

CFM 6000 MIN. OA \_\_\_\_\_ SP .5 IN. WC RPM 365 BHP \_\_\_\_\_

ROOM	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
K 2	1	SR	20' Ø	2.10	1376	3000	1407	3756				
K 2H	2	1	20' Ø	2.18	1376	3000	1359	2951				
						6000		6007				

**POWER EXHAUST FAN DATA**

MFG. \_\_\_\_\_ MODEL \_\_\_\_\_ HP \_\_\_\_\_ F.L.A. \_\_\_\_\_  
 CFM @ MIN. \_\_\_\_\_ ROOM PRESS. @ MIN. \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_  
 CFM @ MAX \_\_\_\_\_ ROOM PRESS. @ MAX \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_

REMARKS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

# CIRCO System Balance, Inc.

SB JOB# \_\_\_\_\_  
 SECTION \_\_\_\_\_ PAGE \_\_\_\_\_  
 DATE 6-1-09

## FAN & OUTLET TEST SHEET WITH POWER EXHAUST

REA SERVED Prep Hood MAKE-UP MAX UNIT EC-2

**MC** FOR NAMEPLATE DATA

MFG MALATHON FR 5670  
 HP 1 V 208 FLA 6.4  
 PH 1 SF 115 RPM 1725

SH AVE DATA:  
 DIA NL 4.4 SHAFT 5/8  
 ADJ % 0 MID FIXED \_\_\_\_\_

**FA** NAMEPLATE DATA

MFG CHAMPION  
 MODEL # 8500SD  
 TYPE EVAP  
 SIZE \_\_\_\_\_

SH AVE DATA:  
 DIA AK 14.4 SHAFT 1"  
 BELTS (1) 46890

DATA	TEST 1	TEST 2	ECON. MODE
VOLTS	<u>210</u>		
AMPS	<u>6.1</u>		
B.H.P.	<u>.95</u>		
ROOM PRES.			
R.P.M.	<u>418</u>		
S.P. -	<u>.11</u>		
S.P. +	<u>.27</u>		
T.S.P.	<u>.38</u>		
FILTER S.P.	<u>.11</u>		
CFM TOTAL	<u>5999</u>		
CFM R.A.			
CFM O.A.	<u>100%</u>		<u>100%</u>
CFM P.E.			

**FA** DESIGN DATA

CFM 6000 MIN. OA \_\_\_\_\_ SP 5 IN. WC RPM 360 BHP \_\_\_\_\_

R OM	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
<u>1</u>	<u>3</u>	<u>SR</u>	<u>20" Ø</u>	<u>2.18</u>	<u>1376</u>	<u>3000</u>	<u>1389</u>	<u>3028</u>				
<u>2</u>	<u>4</u>	<u>SL</u>	<u>20" Ø</u>	<u>2.18</u>	<u>1376</u>	<u>3000</u>	<u>1363</u>	<u>2971</u>				
						<u>6000</u>		<u>5999</u>				

**PO** WER EXHAUST FAN DATA

MFG. \_\_\_\_\_ MODEL \_\_\_\_\_ HP \_\_\_\_\_ F.L.A. \_\_\_\_\_  
 CFM @ MIN. \_\_\_\_\_ ROOM PRESS. @ MIN. \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_  
 CFM @ MAX \_\_\_\_\_ ROOM PRESS. @ MAX \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_

RE MARKS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



# CIRCO System Balance, Inc.

SB JOB# \_\_\_\_\_  
 SECTION \_\_\_\_\_ PAGE \_\_\_\_\_  
 DATE 6-1-04

## FAN & OUTLET TEST SHEET WITH POWER EXHAUST

A EA SERVED DINING MAX'S UNIT AC-1

### MOOR NAMEPLATE DATA

MFG \_\_\_\_\_ FR \_\_\_\_\_  
 IP 1.0 V 208 FLA 7.0  
 PH 1 SF \_\_\_\_\_ RPM 3-Speed  
 SHEVE DATA:  
 DIA  SHAFT   
 DJ % \_\_\_\_\_ FIXED \_\_\_\_\_

### FAN NAMEPLATE DATA

MFG \_\_\_\_\_  
 MODEL # DBYA-T060410D  
 TYPE PKG  
 SIZE \_\_\_\_\_  
 SHEVE DATA:  
 DIA  SHAFT   
 BELTS

DATA	TEST 1	TEST 2	ECON. MODE
VOLTS	210	210	
AMPS	4.7	5.0	
B.H.P.	.67	.71	
ROOM PRES.	Med-Speed	High-Speed	
R.P.M.	Direct Drive		
S.P. -	.20	.24	
S.P. +	.16	.22	
T.S.P.	.36	.46	
FILTER S.P.	.07	.07	
CFM TOTAL	1360	1890	
CFM R.A.	1315	1112	
CFM O.A.	-	780	100%
CFM P.E.	-	-	

### FAN DESIGN DATA

CFM 2000 MIN. OA 750 SP \_\_\_\_\_ IN. WC \_\_\_\_\_ RPM \_\_\_\_\_ BHP \_\_\_\_\_

ROOM	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
	1	CD	12" Ø	1.0		400	250		365			
	2					400	250		365			
	3					400	300		380			
	4					400	350		400			
	5					400	300		380			
						2000	1360		1890			
	R-1	CR	14" Ø	1.0		1000	650		550			
	R-2			1.0		1000	650		560			
						2000	1315		1110			

### POWER EXHAUST FAN DATA

MFG \_\_\_\_\_ MODEL \_\_\_\_\_ HP \_\_\_\_\_ F.L.A. \_\_\_\_\_  
 CFM @ MIN. \_\_\_\_\_ ROOM PRESS. @ MIN. \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_  
 CFM @ MAX \_\_\_\_\_ ROOM PRESS. @ MAX \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_

REMARKS: \_\_\_\_\_



# CIRCO System Balance, Inc.

SB JOB# \_\_\_\_\_  
 SECTION \_\_\_\_\_ PAGE \_\_\_\_\_  
 DATE 6-1-09

## FAN & OUTLET TEST SHEET WITH POWER EXHAUST

A EA SERVED DINING MAX'S UNIT AC-2

MOJ OR NAMEPLATE DATA  
 IFG \_\_\_\_\_ FR \_\_\_\_\_  
 P 1.0 V 208 FLA 7.0  
 H 1 SF \_\_\_\_\_ RPM 3-Speed

SHE VE DATA:  
 IA  SHAFT   
 DJ %  FIXED \_\_\_\_\_

FAN NAMEPLATE DATA  
 IFG \_\_\_\_\_  
 MODEL # YORK DBYA-T060N110D  
 TYPE PK6  
 SIZE \_\_\_\_\_

SHE VE DATA:  
 IA  SHAFT   
 ELTS \_\_\_\_\_

DATA	TEST 1	TEST 2	ECON. MODE
VOLTS	210	210	
AMPS	4.5	5.1	
B.H.P.	.64	.72	
ROOM PRES.	Med-Speed	HIGH-Speed	
R.P.M.	<input checked="" type="checkbox"/> DIRECT DRIVE		
S.P. -	.20	.26	
S.P. +	.18	.20	
T.S.P.	.38	.46	
FILTER S.P.	.07	.07	
CFM TOTAL	1430	1900	
CFM R.A.	1230	(133)	
CFM O.A.	200	765	100%
CFM P.E.			

FAN DESIGN DATA  
 FM \_\_\_\_\_ MIN. OA 750 SP \_\_\_\_\_ IN. WC \_\_\_\_\_ RPM \_\_\_\_\_ BHP \_\_\_\_\_

RC	M	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
		NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
		6	CD	12"Ø	1.0	400	350	350	350				
		7		9"Ø		250	150	240					
		8		9"Ø		250	130	235					
		9		6"Ø		Deleted							
		10		10"Ø		350	200	325					
		11		↓		350	200	325					
		12		↓		350	200	325					
		13	CD	6"		50	100	50					
		14		6"		50	100	50					
						2050	1430	1900					
		R3	CA	10"Ø	1.0	1000	610	560					
		R4	1	1	1	1000	620	575					
						2000	1230	1135					

POWER EXHAUST FAN DATA  
 IFG \_\_\_\_\_ MODEL \_\_\_\_\_ HP \_\_\_\_\_ F.L.A. \_\_\_\_\_  
 CFM @ MIN. \_\_\_\_\_ ROOM PRESS. @ MIN. \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_  
 CFM @ MAX \_\_\_\_\_ ROOM PRESS. @ MAX \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_

REMARKS: #13, 14, ADDED TO RESTROOMS NOT SHOWN  
 ON PLAN. #9 HAS BEEN DELETED



# CIRCO System Balance, Inc.

SB JOB# \_\_\_\_\_  
 SECTION \_\_\_\_\_ PAGE \_\_\_\_\_  
 DATE 6-1-04

## FAN & OUTLET TEST SHEET WITH POWER EXHAUST

REA SERVED KITCHEN HOOD #1 MAX'S UNIT EF-1

MC OR NAMEPLATE DATA  
 MFG A.O. SMITH FR 56H  
 HP 1.5 V 208 FLA 8.2  
 PH 1 SF 120 RPM 1725

SHI VE DATA:  
 DIA 1 1/2 SHAFT 5/8  
 ADJ % MAX \_\_\_\_\_ FIXED \_\_\_\_\_

FAI NAMEPLATE DATA  
 MFG DALTON  
 MODEL # BLFGP22  
 TYPE CENT  
 SIZE \_\_\_\_\_

SHI VE DATA:  
 DIA 15" SHAFT 1 3/16  
 BELTS DA-80

DATA	TEST 1	TEST 2	ECON. MODE
VOLTS	<u>215</u>	<u>210</u>	
AMPS	<u>7.5</u>	<u>8.0</u>	
B.H.P.	<u>1.3</u>	<u>1.46</u>	
ROOM PRES.			
R.P.M.	<u>420</u>	<u>486</u>	
S.P. -	<u>.65</u>	<u>.72</u>	
S.P. +	<u>-</u>	<u>-</u>	
T.S.P.	<u>.65</u>	<u>.72</u>	
FILTER S.P.			
CFM TOTAL	<u>4999</u>	<u>6027</u>	
CFM R.A.			
CFM O.A.			<b>100%</b>
CEM.P.E.			

FAI DESIGN DATA  
 CFM 6000 MIN. OA \_\_\_\_\_ SP \_\_\_\_\_ IN. WC \_\_\_\_\_ RPM \_\_\_\_\_ BHP \_\_\_\_\_

ROOM	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
<u>K.H.</u>	<u>1</u>	<u>FILT</u>	<u>19X19</u>	<u>2450</u>	<u>245</u>	<u>6000</u>	<u>202</u>	<u>4999</u>	<u>246</u>	<u>6027</u>		

POWER EXHAUST FAN DATA  
 MFG \_\_\_\_\_ MODEL \_\_\_\_\_ HP \_\_\_\_\_ F.L.A. \_\_\_\_\_  
 CFM @ MIN. \_\_\_\_\_ ROOM PRESS. @ MIN. \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_  
 CFM @ MAX \_\_\_\_\_ ROOM PRESS. @ MAX \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_

RE MARKS: HOOD 60 S.F.

# CIRCO System Balance, Inc.

SB JOB# \_\_\_\_\_  
 SECTION \_\_\_\_\_ PAGE \_\_\_\_\_  
 DATE 6-1-04

## FAN & OUTLET TEST SHEET WITH POWER EXHAUST

REA SERVED KITCHEN HOOD #2 MAX'S UNIT EF-2

**MOTOR NAMEPLATE DATA**  
 MFG A.O.SMITH FR SLW  
 HP 1.5 V 208 FLA 8.2  
 PH 1 SF 120 RPM 1725

**SHAFT DATA:**  
 DIA 1.640 SHAFT 5/8  
 ADJ %  MAX FIXED \_\_\_\_\_

**FAN NAMEPLATE DATA**  
 MFG DAYTON  
 MODEL # BLFGP22  
 TYPE CENT  
 SIZE \_\_\_\_\_

**SHAFT DATA:**  
 DIA 1.5" SHAFT 1 3/16  
 BELTS 1) A-80

DATA	TEST 1	TEST 2	ECON. MODE
VOLTS	210	210	
AMPS	7.6	8.1	
B.H.P.			
ROOM PRESS.			
R.P.M.	422	489	
S.P. -	.63	.71	
S.P. +	-	-	
T.S.P.	.63	.71	
FILTER S.P.			
CFM TOTAL	5047	6076	
CFM R.A.			
CFM O.A.			100%
CFM P.E.			

**FA DESIGN DATA**  
 CFM 6000 MIN. OA \_\_\_\_\_ SP \_\_\_\_\_ IN. WC \_\_\_\_\_ RPM \_\_\_\_\_ BHP \_\_\_\_\_

ROOM	OPENING			FACTOR	DESIGN		TEST 1		TEST 2		TEST 3	
	NO.	TYPE	SIZE		FPM	CFM	FPM	CFM	FPM	CFM	FPM	CFM
KCH	2	FIL	14"14"X16"	24.50	245	6000	206	5047	248	6076		

**POWER EXHAUST FAN DATA**  
 MFG \_\_\_\_\_ MODEL \_\_\_\_\_ HP \_\_\_\_\_ F.L.A. \_\_\_\_\_  
 CFM @ MIN. \_\_\_\_\_ ROOM PRESS. @ MIN. \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_  
 CFM @ MAX \_\_\_\_\_ ROOM PRESS. @ MAX \_\_\_\_\_ IN. WC \_\_\_\_\_ Hz \_\_\_\_\_

REMARKS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**APPLICATION FOR COMMERCIAL BUILDING PERMIT**

**CITY OF SACRAMENTO  
BUILDING DIVISION**

**PERMIT SERVICES SECTION**

NORTH OFFICE: 2101 Arena Blvd., Ste. 200  
Sacramento, CA 95834 (916) 808-2534 FAX 808-7046  
CENTRAL CITY: 1231 I Street, Rm. 200  
Sacramento, CA 95814 (916) 808-2534 FAX 264-5987

ACTIVITY #

Insp. Area

0313364



**Applicant MUST complete  
ALL Unshaded areas**

ADDRESS 6051 MACK ROAD, SACRAMENTO CA 95823 Suite \_\_\_\_\_

PARCEL # \_\_\_\_\_

<p align="center"><b>CONTACT</b></p> <p>Name <u>LEO CHO</u></p> <p>Street Address <u>550 S. WILTON PL.</u></p> <p>City/ State/ Zip <u>LOS ANGELES, CA 90020</u></p> <p>Phone <u>213. 387. 7788</u> FAX <u>213. 387. 4567</u></p> <p>E-mail: <u>GPLA@GPINC. US</u></p> <hr/> <p align="center"><b>ARCHITECT/ENGINEER</b></p> <p>Name <u>LEO CHO</u></p> <p>Address <u>550 S. WILTON PL.</u></p> <p>City/ State/ Zip <u>LOS ANGELES</u></p> <p>Phone <u>213. 387. 7788</u> FAX <u>(213) 387. 4567</u></p> <p>E-mail: <u>GPLA@GPINC. US</u></p>	<p align="center"><b>LICENSED CONTRACTOR</b></p> <p>Lic No.# _____</p> <p>Name _____</p> <p>Address _____</p> <p>City/ State/ Zip _____</p> <p>Phone _____ FAX _____</p> <p>E-mail: _____</p> <hr/> <p align="center"><b>OWNER</b></p> <p>Name <u>RAMON SARROSANTOS / STEVE GO</u></p> <p>Address <u>8231 WOODMAN AVE.</u></p> <p>City/ State/ Zip <u>PANORAMA CITY CA 91402</u></p> <p>Phone <u>(626) 705. 3036</u> FAX _____</p> <p>E-mail: _____</p>
--	---

→ Will permittee have any employees on the jobsite?  No  Yes → INSURANCE CO: \_\_\_\_\_

→ WORKER'S COMPENSATION POLICY # \_\_\_\_\_ EXPIRATION DATE: \_\_\_\_\_

NATURE OF WORK IN DETAIL: T.I. - new restaurant

OCCUPANT/TENANT: Max's of Manila VALUATION: \$ 370,000.

FLOOD STATUS:				S.C.A.T.						
JOB DESCRIPTION		BLDG	SHELL	APT	TI	REM	SW	FIRE	ADD	OTH
INSPECTION DISCIPLINES			BLDG	MECH	PLUMB	ELEC		SITE		FIRE
# Stories	1st flr Area	Total Area	Use Zone	Occp Group	Const type	Fire Req. Y / N		Fed Code	Vio. File	
						SPR	ALARM		[H]	[Quad]
B	L	P	M	E	F	S		D	PW	UTIL

COMMENTS: \_\_\_\_\_

REGIONAL SANITATION FEES?  Yes  No HEALTH DEPARTMENT?  Yes  No

WATER FLOW TEST FOR NEW BUILDINGS OR ADDITIONS?  Provided  Faxed



550 South Wilton Place  
Los Angeles, CA 90020  
Tel 213. 387. 7788  
Fax 213. 387. 4567

**Grace  
Partnership, Inc.**

# Memorandum

<b>To:</b> Building Inspector	<b>From:</b> Leo Cho
<b>Company:</b> City of Sacramento, Building Division 12311 I St., #200, Sacramento, CA 95814	<b>Date:</b> 5/17/04
<b>Project:</b> Max's of Manila (Bldg. Permit # 0313364) Reference: Detail 4 & 6 / A3.1	<b>Cc:</b> Focus Construction Ramon S.

Dear Sir:

The purpose of this memorandum is to acknowledge that the use of 3/8" diameter rod, in lieu of 5/8", is acceptable to support the trellis as detailed in 4 & 6/A-3.1.

Sincerely,

Leo Cho  
Architect  
Grace Partnership, Inc.

