

CITY OF SACRAMENTO

Permit No: 0518714

1231 I Street, Sacramento, CA 95814

Insp Area: 2

Thos Bros: 337E2

Site Address: 2801 65TH AV SAC

Sub-Type: ASFR

Parcel No: 049-0201-008

Housing (Y/N): N

CONTRACTOR
OWNER BUILDER

OWNER
SHARMA BRIJESH P/REENA R.
2801 65TH AV
SACRAMENTO, CA 95822

ARCHITECT

**Nature of Work: ADD 3109 SF (1ST FLR: 630 SF LIVABLE, 54 SF PORCH; 2ND FLR: 2249 SF LIVABLE, 176 SF DECK) TO 1-
RMDL 564 SF OF (E) SFD**

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class _____ License Number 0 Date _____ Contractor Signature _____

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____
Date 1-25-06 Owner Signature B Sharma

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant has verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 1-25-06 Applicant/Agent Signature B Sharma

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:
I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier _____ Policy Number _____ Exp Date _____

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 1-25-06 Applicant Signature B Sharma

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

PAID
CITY OF SACRAMENTO
JAN 25 2006
NEWBOROUGH
AND DEVELOPMENT



17407 Penn Valley Drive Suite 5103
 Penn Valley, CA 95846
 Voice: 530-280-2222
 Fax: 530-432-9891
 CaimanEng@earthlink.net

April 28, 2006

PLEZ MICROFILM

City of Sacramento
 Planning and Building Department
 2101 Arena Blvd, Suite 200
 Sacramento, CA 96834


Subject: Sharma Addition
 2801 65th Ave.
 Sacramento, CA
 Caiman Job No. 05-180
 Correction Notice

0518714

2. Hanger HGLTV5 is an acceptable replacement for the EG5. Loads checked. Load from Beam 8 is 6,124 lbs and capacity of hanger is 7,800 lbs. Files and cut sheets attached.
3. Beam 8 is being supported by Beam 6 as shown in calculations. The load rating of beam 6 is at 80.69% as shown in the attached calculation sheet.
5. Detail modified. Printout of revised detail 5 attached.

If you have any questions, please don't hesitate to call me at 530-432-9891.

Sincerely,



Roger Blair P.E.
 Caiman Engineering Inc.