

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0503214

Insp Area: 3

Thos Bros: 318D7

Site Address: 8205 BERRY AV SAC

Parcel No: 040-0111-007

Sub-Type: NOTHR

Housing (Y/N): N

CONTRACTOR

FLINTCO INC
PO BOX 490
TULSA OK 74101

OWNER

SERVICES DEVELOPMENT CORPORATION
1550 51ST ST
SACRAMENTO CA 95819

ARCHITECT

Nature of Work: CONSTRUCT FIRE PROTECTION WATER STORAGE TANK -RELATED TO PERMIT #0407060

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name _____ Lender's Address _____

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class _____ License Number 702469 Date 7-12-05 Contractor Signature *Jay Walsh*

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. _____ B & PC for this reason: _____
Date _____ Owner Signature _____

PAID
CITY OF SACRAMENTO
JUL 12 2005
PERMIT CENTER

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 7-12-05 Applicant/Agent Signature *Jay Walsh*

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:
I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier ST PAUL FIRE & MARINE INS Policy Number WVK9102239 Exp Date 06/01/2006

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 7-12-05 Applicant Signature *Jay Walsh*

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

Intertek**ETL SEMKO****Permit # 0503214**

ATTN: Jay W.

January 24, 2006

RECEIVED

Report No. 3080001P

Project No. 3080000

Ph: (706) 297-2838

Fx: (916) 383-5703

Mr. Steve Dickson
Patterson Pump Co.
9201 Ayersville Road
Toccoa, GA 30577

FEB 07 2006

FLINTCO. INC.

Subject: ETL Field Evaluation Report of a Patterson Pump House for compliance to the requirements contained in the Standard for Motor-Operated Water Pumps, ANSI/UL 778, 4th Edition, 2002, referencing also NFPA 70 – 2005 (National Electric Code) and the Standard for Industrial Control Equipment, UL 508, 17th Edition, 1999.

Dear Mr. Dickson,

We have completed our evaluation of the above referenced equipment and found the equipment to be in compliance with the referenced standards. The products were subjected to the requirements contained in the following Safety Standards:

- Motor-Operated Water Pumps, ANSI/UL 778, 4th Edition, 2002
- NFPA 70 – 2005 (National Electric Code)
- Industrial Control Equipment, UL 508, 17th Edition, 1999


The system covered by this evaluation consists of a UL Listed Pump House structure enclosing a UL Listed Diesel Engine Controller and a UL Listed Diesel Engine, a UL and ETL Listed Jockey Pump Controller powering a UL Recognized Pump Motor, and all associated building wiring and lighting equipment. The structure is supplied with 460 V, 3Ph, 60 Hz, 30 A power at a Listed switch located on the outside rear of the housing structure.

This investigation was authorized by Agreement No. 136654. The investigation was begun and concluded on 01/23/06. Please note, although this report indicates the sample evaluated was found to comply with the requirements as stated, this report is preliminary and will be followed by a formal report for your records. A new sample in good condition was made available and evaluated at the location identified on the attached **Letter of Compliance**.

At the conclusion of this evaluation, the subject equipment was labeled with an ETL Serialized Field Label under the conditions indicated in the attached **Letter of Compliance**.

If you have any questions, please feel free to contact us at your convenience. We are looking forward for future opportunities to work together.

Sincerely,



Phil C. Mason
Staff Engineer
Intertek - Menlo Park

MICROFILM AT FINAL

An Independent Organization Testing for Safety and Performance

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report by itself does not imply that the material, product or service is or has ever been under an Intertek certification program.

Intertek Testing Services NA, Inc.
1365 Adams Court, Menlo Park, CA 94025
Telephone: +1 650-463-2900 Fax: +1 650-463-2910 Web: www.ettsemko.com



Applicant: Mr. Steve Dickson
Patterson Pump Co.
9201 Ayersville Road
Toccoa, GA 30577

Equipment Location: FedEx Hub Expansion, 8205 Berry Ave., Sacramento, CA 95828

Equipment Description: Patterson Pump House including pump, engine, and associated control equipment

Evaluation Date: January 23rd, 2005


Standards: Motor-Operated Water Pumps, ANSI/UL 778, 4th Edition, 2002

Manufacturer	Model	Serial No.	Electrical Ratings	ETL Label
Patterson Pump Co.	12X8MAA	FP-C048204	(Pump House) 460 V, 3 Ph, 60 Hz, 30 A	255238

The equipment noted in this Report and Letter of Compliance has been investigated to the referenced safety standards and as far as practical in the field and has been found to be in essential compliance with those requirements. The installation methods and final approvals at the installation site are the responsibility of the Authority Having Jurisdiction. Complete investigation information is on file at this office.

Please note, this Letter of Compliance does not represent authorization for the use of the ETL Listing Mark. Please also note, a formal letter report for your files will follow this report.

Prepared By:



Phil C. Mason
Staff Engineer
Intertek - Menlo Park

