

CITY OF SACRAMENTO

Permit No: 9812147

1231 I Street, Sacramento, CA 95814

Insp Area: 3

Site Address: 8386 ROVANA CR SAC

Sub-Type: ACOM

Parcel No: 0640010129

Housing (Y/N): N

CONTRACTOR

CAL RAM
1891 ENTERPRISE
W SARAMENTO CA 95691

OWNER

RICK MASSIE
PO BOX 276043
SAC CA 95827

ARCHITECT

Nature of Work: INSTALL TASK LIGHTING , ELEC HOOKUPS OF PRESS AND BINDRY EQUIPMENT

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name Lender's Address

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

X License Class B License Number 446622 Date 12-9-98 Contractor Signature Shell Qualley

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. B & PC for this reason:

Date Owner Signature

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

X Date 12-9-98 Applicant/Agent Signature Shell Qualley

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

X Carrier CAL Comp Ins Co Policy Number W9841080722 Exp Date 4-1-99

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

X Date 12-9-98 Applicant Signature Shell Qualley

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.



INSPECTION CONSULTANTS INC.

Fax Cover Sheet

Number of pages transmitted _____ (including cover sheet)

Date: 4/11/99

Phone: _____

Fax: 264-8370

To: Fred Wagner

From: Eric France

V.P. Construction

Services

Subject: Electrical Inspection for Georges and Shapiro

Message:

If you do not receive all pages please contact our office.

**INSPECTION CONSULTANTS, INC.**

Date: March 12, 1999
File: 991-013
Client: Georges - Shapiro Lithograph
8386 Rovana Cir.
Sacramento, CA 95828
Attention: Mr. Ed Georges
Date of Inspection: February 10, 1999
Date of Re-Inspection: February 26, 1999
Purpose of Inspection: Verify that manufactured equipment meets NFPA 79 and other electrical codes
Purpose of NFPA 79: The purpose of NFPA No. 79 is to provide detailed information for the application of electrical/electronic equipment, apparatus, or systems supplied as part of industrial machinery that will promote safety to life and property.
Local Authority: City of Sacramento

Inspection Report:

On February 10, 1999, a representative of our firm visited the Georges - Shapiro Lithograph facility in Sacramento, California, to perform inspection of the following equipment:

Equipment Description:

- 1 Heidelberg Drusk Mashinen model 72-S press s/n 524246
- 2 Heidelberg press s/n 9830
- 3 KS Macy Machine Co. Omegabinder s/n 500201
- 4 KS Macy Machine Co. Omegabinder s/n 510255
- 5 KS Macy Machine Co. Omegabinder s/n 530110


**Georges-Shapiro Lithograph
Sacramento, California
ICI File No.: 991-013
Page No. 2**

6. Polar model 115EM paper cutter s/n 5831298
7. Welotro model 7112 Shrinkwrap s/n GP62870
8. Stahl folder s/n 33406-136096 TF66/40
9. Stahl folder s/n 33406-136096 RF66V
10. Stahl folder s/n 33406-136096 3.TF56/4KB
11. Stahl folder s/n 33406-136096 2. TF66/4QC
12. Stahl folder s/n 23306-4944-FA

The above equipment was checked per the NFPA 79 checklist. Items 1 through 7 substantially met the requirements of NFPA and were stickered. Non-compliance conditions were noted on items 8-12 and brought to the attention of Mr. Ed Georges. A re-inspection was scheduled for February 26, 1999, and at that time the equipment substantially met the requirements of NFPA 79 and were stickered.

If you have any questions, or require additional information, please contact our office at (916) 635-2972.

**Sincerely,
INSPECTION CONSULTANTS, INC.**



John Stubban, P.E.
Staff Electrical Engineer



INSPECTION CONSULTANTS, INC.

Date: March 12, 1999

File: 991-013

Client: Georges - Shapiro Lithograph
8386 Rovana Cir.
Sacramento, CA 95828

Attention: Mr. Ed Georges

Date of Inspection: February 10, 1999
Date of Re-Inspection: February 26, 1999

Purpose of Inspection: Verify that manufactured equipment meets NFPA 79 and other electrical codes

Purpose of NFPA 79: The purpose of NFPA No. 79 is to provide detailed information for the application of electrical/electronic equipment, apparatus, or systems supplied as part of industrial machinery that will promote safety to life and property.

Local Authority: City of Sacramento

Inspection Report:

On February 10, 1999, a representative of our firm visited the Georges - Shapiro Lithograph facility in Sacramento, California, to perform inspection of the following equipment:

Equipment Description:

1. Heidelberg Drusk Mashinen model 72-S press s/n 524246
2. Heidelberg press s/n 9830
3. KS Macy Machine Co. Omegabinder s/n 500201
4. KS Macy Machine Co. Omegabinder s/n 510255
5. KS Macy Machine Co. Omegabinder s/n 530110


Georges-Shapiro Lithograph
Sacramento, California
ICI File No.: 991-013
Page No. 2

6. Polar model 115EM paper cutter s/n 5831298
7. Welotro model 7112 Shrinkwrap s/n GP62870
8. Stahl folder s/n 33406-136096 TF66/40
9. Stahl folder s/n 33406-136096 RF66V
10. Stahl folder s/n 33406-136096 3.TF56/4KB
11. Stahl folder s/n 33406-136096 2. TF66/4QC
12. Stahl folder s/n 23306-4944-FA

The above equipment was checked per the NFPA 79 checklist. Items 1 through 7 substantially met the requirements of NFPA and were stickered. Non-compliance conditions were noted on items 8-12 and brought to the attention of Mr. Ed Georges. A re-inspection was scheduled for February 26, 1999, and at that time the equipment substantially met the requirements of NFPA 79 and were stickered.

If you have any questions, or require additional information, please contact our office at (916) 635-2972.

Sincerely,
INSPECTION CONSULTANTS, INC.



John Stubban, P.E.
Staff Electrical Engineer



INSPECTION CONSULTANTS INC.

Project Name Georges - Shapiro	Client or Owner Georges - Shapiro Lithograph	Job No. 991-013
General Location of Work	Owner or Clients Representative	Date-Day of Week 2-10-99
General Contractor	Subcontractor	Project Engineer
Type of Work	Subcontractor's Superintendent or Foreman	Permit No.
Assignment Cancelled By:	Page 2 of 2	Weather
		Technician Jerry Johnson

Daily Field Report Item 8 :

A. Stop button body turns when the button is reset.

B. Cable to control station not in connector.

Item 9 :

A. Stop button body turns when the button is reset

B. Incoming ground conductor not identified.

Item 10

A. Stop button body turns when the button is reset.

Item 11

A. Stop button body turns when the button is reset.

Item 12.

A. No working room in front of control panel. Move panel so there is three ft. of working room in front of it.

The flexible conduit feeding Item 7 is pulled apart and needs to be replaced.

Conformance

Non-compliance conditions noted were brought to the attention of Ed Georges for corrective action. Work observed was to the best of my knowledge, in conformance with the (approved) project plans specification and applicable standards of workmanship; with the exception of items noted above.

Comments Attached

Inspector [Signature]



INSPECTION CONSULTANTS INC.

Project Name Georges - Shapiro	Client or Owner Georges - Shapiro Lithograph	Job No. 991-013
General Location of Work Sacramento	Owner or Clients Representative Ed Georges	Date-Day of Week 2-10-99 Wed.
General Contractor	Subcontractor	Project Engineer
Type of Work Electrical Inspection	Subcontractor's Superintendent or Foreman	Permit No.
Assignment Cancelled By:	Page 1 of 2	Weather
		Technician Jerry Johnson

Daily Field Report I viewed the following machines :

1. Heidelberg Drusk Maschinen model 72-S press s/n 524246
2. Heidelberg press s/n 9830
3. KS Macy Machine Co. Omegabinder s/n 500201
4. KS Macy Machine Co. Omegabinder s/n 510255
5. KS Macy Machine Co. Omegabinder s/n 530110
6. Polar model 115EM paper cutter s/n 5831298
7. Welotro model 7112 Shrinkwrap s/n GP62870
8. Stahl folder s/n 33406-136096 TF66/40
9. Stahl folder s/n 33406-136096 RF66V
10. Stahl folder s/n 33406-136096 3.TF56/4KB
11. Stahl folder s/n 33406-136096 2.TF66/4QC
12. Stahl folder s/n 23306-4944-FA

The above equipment was checked per the NFPA 79 checklist. Items 1 through 7 substantially met the requirements of NFPA79 and were stickered.

Conformance

Non-compliance conditions noted were brought to the attention of _____ for corrective action. Work observed was to the best of my knowledge, in conformance with the (approved) project plans specification, and applicable standards of workmanship; with the exception of items noted above.

Comments Attached

Inspector _____



INSPECTION CONSULTANTS INC.

Project Name Georges - Shapiro	Client or Owner Georges - Shapiro Lithograph	Job No. 991-013R
General Location of Work Sacramento	Owner or Clients Representative Ed Georges	Date-Day of Week 2-26-99 Friday
General Contractor	Subcontractor	Project Engineer
Type of Work Electrical Inspection	Subcontractor's Superintendent or Foreman	Permit No.
Assignment Cancelled By:	Page 1 of 1	Weather
		Technician Jerry Johnson

Daily Field Report

Stahl folder s/n 33406-136096 TF66/40 (item 8 report dated 2-10-99)

A. Stop button body does not now turn when reset.

B. Cable to control station is in connector.

Stahl folder s/n 33406-136096 RF66V (item 9 report dated 2-10-99)

A. Stop button body does not now turn when reset.

B. Incoming ground conductor is now identified.

Stahl folder s/n 33406-136096 3.TF56/4KB (item 10 report dated 2-10-99)

A. Stop button body does not now turn when reset.

Stahl folder s/n 33406-136096 2.TR66/4QC (item 11 report dated 2-10-99)

A. Stop button body does not now move when reset.

Stahl folder s/n 23306-4944-FA (item 12 report dated 2-10-99)

A. Control panel was moved so that there is 3 ft. of working room in front of it.

Flexible conduit was replaced to Welotro shrinkwrap .

The above equipment substantially met the requirements of NFPA 79 was stickered

Conformance

Non-compliance conditions noted were brought to the attention of _____ for corrective action. Work observed was to the best of my knowledge, in conformance with the (approved) project plans specification and applicable standards of workmanship; with the exception of items noted above.

Comments Attached

Inspector _____