

597 7140-181

E. of BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD **\$161.00**

**Lot 6, Blk. O & P,
23rd and 24th Sts.**

TYPE BUILDINGS

R106 7174

PERMIT NO. E-809	LOCATION 2321 - P Street A-2
DATE Mar. 15-62	PURPOSE Const. 2-story Office Building
ZONE R-1	OWNER Jack Mingo 1313 -21st Street
	ARCH'T Starks, Jozens, Nacht 5701-Freeport
	CONTR John Otto 4322-24th St. GL 2-4311

VAL. \$61,000.	STORIES 2	ROOMS	APTS. 2,370-2nd SIZE
			2,370 sq. ft.

INSP.	DATE	BLDG. TYPE V-NO HOUR	OCCUPANCY GROUP F-2
--------------	-------------	------------------------------------	-----------------------------------

FORM	<i>3-23-62</i>	<i>Basalts</i>
-------------	----------------	----------------

JOIST		
--------------	--	--

FRAME	<i>4-27-62</i>	<i>Basalts</i>
--------------	----------------	----------------

SHEET ROCK	<i>6-26-62</i>	<i>Basalts (2nd floor)</i>
-------------------	----------------	----------------------------

FINAL	<i>8/6/62</i>	<i>R. L. Smith</i>	<i>Ent Com.</i>
--------------	---------------	--------------------	-----------------

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
4-17-62	OK w/ ductwork Barbits
4-24-62	OK w/ partial steel, all plywood sheetrock walls. OK to install ceiling
	3rd floor Barbits
4-26-62	VERTICAL SHAFT NOT REQ'D. ON DUCTS BUT MUST PROVIDE DAMPERS WHERE PIERCING FLOOR. OK QD PER OTTO
7-17-62	PT Final - Parking area not paved <i>Count</i>
9-30-62	PT Final - Not ready <i>Count</i>
	<div style="display: flex; justify-content: space-between;"> COMPLETE AND OK INSPECTOR </div>