

~~R159 7430~~

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

\$259.50

Blk. bounded by
24th, 25th S & T Streets

TYPE BUILDINGS

R159 7430-455

R193 7255-256 Pile

PERMIT NO.

E-9375

LOCATION

2423 - T Street

A-2

DATE

Jan. 21-65

PURPOSE

Const. 16-unit Apartment House

OWNER

Charles Fisher 4555-Auburn Blvd.

ZONE

R-4

ARCH'T

Leo McGlade

CONTR

Fisher Const. 4555-Auburn Blvd.

VAL. \$139,600.

STORIES

3

ROOMS

APTS.

16

5,340-3rd flr.

4,800-2nd flr.

5,530 sq. ft. p.

INSP.

DATE

1-29-65

BLDG.

TYPE V-1 hr.

OCCUPANCY

GROUP H-1

PHONE (O) IC

483-4517

FORM

ok except Carpet area. - Larsen

JOIST

FRAME

4-27-65

E Larsen

SHEET

ROCK

4-30-65

5-2-65

2nd floor E Larsen
3rd floor E Larsen

FINAL

5-2-66

M. Callaway

Int Com

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
1-28-65	P.T. not ready Larsen
2-15-65	Red Tag. Inspected not correct for water
2-16-65	A.T. no Barricade yet. No plans - bolts missing. - Larsen
2-17-65	O.K. Lab. Fuller
4-6-65	P.T. Roof + Wall nail - (nails driven to deep) Larsen
4-14-65	Ok Roof + Wall nail Larsen
4-14-65	P.T. STUCCO WORK NOT COMPLETE - Check
4-21-65	P.T. Not ready Larsen
4-23-64	Ok Frame on 1st floor. Larsen
7-28-65	1/2" Faced C SR not needed Larsen
5-3-65	P.T. no plans on job. Hammond
5-10-65	COMPLETE AND OK INSPECTOR poured; unable to inspect Ruth

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD					
Blk. bounded		\$259.50			
by 24th, 25th S & T Streets		TYPE BUILDINGS		Card #2	
PERMIT NO.	LOCATION				
E-9375	2423 - T Street				A-2
DATE	PURPOSE				
Jan 21-65	Const. 16-Unit Apartment House				
ZONE	OWNER				
R-4	Charles Fisher 4555-Auburn Blvd.				
	ARCH'T				
	Leo McGlade				
	CONTR				
	Fisher Const.	Same	5,340	3rd floor	
VAL	\$139,600.	STORIES	ROOMS	APTS.	4,800 2nd fl.
		3		16	5,530 sq. ft.
INSP.	DATE	BLDG. TYPE	OCCUPANCY GROUP	PHONE (O) (C)	
FORM					
JOIST					
FRAME					
SHEET ROCK					
FINAL					

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
5-11-65	PT Mails missing in RR <i>broken</i>
6-16-65	PT Mails - 1 box - liquid water on all of <i>broken</i> utility - 50000'
8-18-65	PT Mails - One pipe column - <i>protected</i> <i>3000'</i>
COMPLETE AND OK	INSPECTOR