

R285 F79-86

W ¹ / ₂ Lot 2, BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD		\$184.50	
Blk 26th-27th, Q-R Streets		TYPE BUILDINGS <i>R280</i> <i>fireplace</i> <i>FI yoking</i>	
PERMIT NO. G-7515	LOCATION 2610 - Q Street	A-2 (13)	
DATE 7-13-70	PURPOSE Construct 7-unit apartment house		
ZONE R-5	OWNER E.K.Purdy, 1060 Sand Bar Cir., Carm.		
	ARCH'T L.McGlade, 2011 Arden Way, Sacto.		
	CONT'R Owner same	483-7521	
VAL. \$72,000.	STORIES 2	ROOMS	APTS. 7
			SIZE 6,582-sq.ft.
INSP.	DATE	BLDG. TYPE V-No hour	OCCUPANCY GROUP H-1
FORM			PHONE (O) (C)
JOIST			
FRAME	<i>9-5-70</i>	<i>E. M. ...</i>	
SHEET ROCK	<i>4-8-70</i>	<i>Hamm...</i>	
FINAL	<i>10-8-70</i>	<i>J. ...</i>	<i>10-8-70</i>

activity seen

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
2-20-70	P.M. - 4' slab - not ready <i>Barbute</i>
2-23-70	P.M. - 4' slab - not ready <i>Barbute</i>
2-27-70	P.M. - 4' slab <i>Barbute</i>
2-28-70	P.M. - not ready <i>Barbute</i>
2-24-71	P.M. - not ready <i>Barbute</i>
2-3-70	P.M. - not ready <i>Barbute</i>
2-4-70	P.M. - not ready <i>Barbute</i>
2-21-70	P.M. fireplace steel <i>Barbute</i>
2-24-70	P.M. 4' slab not complete <i>Barbute</i>
2-25-70	P.M. long nail <i>Barbute</i>
2-1-70	P.M. frame - not ready <i>Barbute</i>
2-24-70	P.M. steel - not ready <i>Barbute</i>
2-11-70	P.M. steel not ready <i>Barbute</i>
2-1-70	on final it was visible to see that the fire places were encased in with in 3 1/2' footing, when exposed to shape additional footing were poured and vertical steel added.
	COMPLETE AND OK <i>Barbute</i> INSPECTOR

BUILDING DIVISION — BUILDING INSPECTOR'S REPORT CARD

TYPE BUILDINGS

Card #2

PERMIT NO. G-7515		LOCATION 2610 - Q Street A-2 (13)			
DATE Jul-13-70		PURPOSE Const. 7-unit apartment house			
ZONE R-5		OWNER E. K. Purdy 1060-Sand Bar Cir, Carm.			
		ARCH'T L. McGlade 2011-Arden Way			
		CONTR Owner Same 483-7521			
VAL. \$72,000.		STORIES 2	ROOMS	APTS. 7	SIZE 6,582 sq. ft.
INSP.	DATE	BLDG. TYPE		OCCUPANCY GROUP	PHONE (O) (C)
FORM					
JOIST					
FRAME					
SHEET ROCK					
FINAL					

DATE	SPECIAL CONDITIONS OF WORK — REMARKS
10-1-70	<i>P. G. Ginnel - not inspected</i>
10-2-70	<i>Leakage tank. no cover needed per fire & elec. engineer requested</i>
COMPLETE AND OK	INSPECTOR