

CITY OF SACRAMENTO

Permit No: 9900995

1231 I Street, Sacramento, CA 95814

Insp Area: 4

Site Address: 1431 WOODSIDE GLEN WY SAC RES

Sub-Type:

Parcel No: 2250466006

Housing (Y/N): N

CONTRACTOR

CERTIFIED RESTORATION
9911 HORN RD #150
SACRAMENTO CA

OWNER

WHICHARD BENJAMIN O/FLORENCE
400 FLORIN RD
SACRAMENTO CA

ARCHITECT

Nature of Work: LIKE FOR LIKE REPAIR OF FIRE DAMAGED HOUSE

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name Lender's Address

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 677024 Date 2-2-99 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. B & PC for this reason: Date Owner Signature

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 2-2-99 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier CREDIT GENERAL INDEMNITY Policy Number TWC194004900 Exp Date 01/01/2000

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 2-2-99 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

Sacramento Fire Department - Incident Report

Incident No : 980044860 Call# : 98098079 Date: 10/21/98 Time: 17:16
Address : 1431 WOODSIDE GLEN WY
Type : 11 BUILDING FIRE
Action Taken: 15 EXTINGUISHED
Property : 1-2 FAMILY RESIDENTIAL: SINGLE FAMILY
UBC : DWELLINGS AND LODGING HOUSES

Weather : 70 Degrees / Clear
Resources : 1 Engine
 4 Other Apparatus

Fire Casualties : None

Fire Damage : Confined to room of origin
Smoke Damage : Confined to structure of origin
Property Loss : \$45,000 Contents Loss :
Property Value : \$125,000 Contents Value:
Area of Origin : Concealed roof/ceiling space
Caused by : Chimney,gas vent flue
Form of Heat : Heat from wood or paper fueled equipment
Ignition Factor : Installed too close to combustibles
Type of Material : Sawn woods,finished lumber
Form of Material : Structural member,framing
Type of Material : Sawn woods,finished lumber
Form of Material : Structural member,framing
Smoke Travel : Air handling duct
Other Factors : Insufficient information
Extinguished by : Water carried on first in unit
Structure Type : Building with one specific property use
Structure Status : In use
 Occupied
Construction Type: Type III - Ordinary
Roof Type : Composition
Number of Stories: 1

Level: A01

Detector Type : Smoke detector - other
Power : Hard Wire
Performance : Detector not in space of origin - did not operate
Reason Failed : Failure of power supply

Extinguishing Sys: No extinguishing system

Report Author : F263