



2.10

DEPARTMENT OF
ADMINISTRATIVE SERVICES

PROCUREMENT SERVICES DIVISION

CITY OF SACRAMENTO
CALIFORNIA

September 26, 2001

PS:Admin:01-47:RBH:SA:bd

5730 24TH STREET
BUILDING FOUR
SACRAMENTO, CA
95822-5699

PH 916-433-6240
FAX 916-399-0263

City Council
Sacramento, California

Honorable Members in Session:

CONTINUED
FROM 10-16-01
TO 10-23-01

SUBJECT: ADOPTION OF SPECIFICATIONS AND AWARD OF BID NO. 1853 FOR BAR SCREENS AND WASHING PRESS FOR SUMP 1A IN A TOTAL AMOUNT NOT TO EXCEED \$249,510.73

LOCATION AND COUNCIL DISTRICT: Citywide

RECOMMENDATION:

Staff recommends that the City Council adopt specifications and accept the lowest responsible bid for the contract resulting from Bid No.1853 for Bar Screens and Washing Press for Sump 1A. Award is recommended to Vulcan Industries, Inc., 121 S. Kirlin Street, Missouri Valley, Iowa 51555, in a total amount not to exceed \$249,510.73.

CONTACT PERSONS:

Bill Miller, Associate Engineer, 264-0105
Steve Alstrom, Senior Buyer, 433-6343

FOR COUNCIL MEETING: October 16, 2001

SUMMARY:

Attached is a tabulation of sealed proposals received by the City Clerk for furnishing material in accordance with the specifications used in the bidding process, and recommendation for award of Bid No.1853 for bar screens and washing press for Sump 1A in a total amount not to exceed \$249,510.73.

BACKGROUND:

Sump 1A is a major combined system pump station which primarily pumps combined sewer from the downtown area during storm events. The station receives debris from storm runoff which collects on the existing trash racks which are in place to protect the pumps from damage. Currently, the accumulation of debris must be manually removed and disposed of. During some storms, the trash gathers on the racks at such a high rate that flows are blocked, resulting in backups in the system and localized flooding. These