

CITY OF SACRAMENTO  
1231 I Street, Sacramento, CA 95814

Permit No: 9808897  
Insp Area: 1

Site Address: 1500 5TH ST SAC  
Parcel No: 0060194036 3RD FLOOR

Sub-Type: REM  
Housing (Y/N): N

CONTRACTOR  
MARK III ENGINEERING  
5101 FLORIN PERKINS RD  
SACRAMENTO CA 95826

OWNER  
PANATTONI MASSIE & OATES  
1500  
SACRAMENTO CA 95819

ARCHITECT

Nature of Work: REMODEL OFFICES ON 2ND & 3RD FLOORS - PHASE 3

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name N/A Lender's Address \_\_\_\_\_

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class B License Number 57413A Date 2/11/98 Contractor Signature [Signature] M3ENY

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_

Date \_\_\_\_\_ Owner Signature \_\_\_\_\_

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 2/11/98 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier ST. COMP. INS. FUND Policy Number 692.97, 2087  
10.1.98

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 2/11/98 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.



# DAILY FIELD REPORT

PAGE 1

Project #: 00168-038.00	Project Name: 5TH & O	Date: 10-8-78	Day: THUR.	Weather:
-------------------------	-----------------------	---------------	------------	----------

Client:	Client's Representative:
---------	--------------------------

Contractor: MARK III	Other Persons Contacted:
----------------------	--------------------------

Type of Work: ANCHOR BOLT PULL TEST	Location of Work: PHASE III
-------------------------------------	-----------------------------

Arrived:	Departed:
----------	-----------

### FIELD ACTIVITIES:

WHLK ON SITE 1 PULL TESTED 16 5/8" ROPED ANCHORS AT THE TUBULAR BEAM HANGERS, 1 PULLED THEM TO OVER 4300 LBS. ALL BOLTS PASSED.

EQUIPMENT ON SITE

Copy given to:	Sample Pick-up: yes <input type="checkbox"/> no <input type="checkbox"/>	Total Time:	Report by: [Signature]
	Type:		

**DAILY FIELD REPORT**

Project #: 00168-038.00	Project Name: 5TH & O STREET	Date: 10-8-98	Day: THUR	Weather:
Client:		Client's Representative: MIKIE		
Contractor: MARK III		Other Persons Contacted:		
Type of Work: FIELD WELDING		Location of Work: PHASE 3 / 3RD FLOOR		
FIELD ACTIVITIES:		Arrived:	Departed:	

WHILE ON SITE I OBSERVED WELDER AARON CRAW WELD THE FULL PEN WELDS IN THE NORTHERN-MOST CHANNEL IN PHASE 3rd 3RD FLOOR. ALL WELDING DONE IN ACCORDANCE WITH RFI DATED JULY 16, 1998, RFI GIVES NO JOINT DIMENSIONS. I ALSO OBSERVED THE WELDING OF FULL PEN WELDS ON THE TWO TUBULAR BEAMS IN THE SOUTH WEST ROOM. ALL WELDING DONE TO AWS SPECIFICATIONS. FURTHER WELDING OBSERVATION NECESSARY. I INITIALED ALL WELDS I EXAMINED.

EQUIPMENT ON SITE

Copy given to: MIKIE	Sample Pick-up: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>	Total Time:	Report by: DANN REGGINIS
-------------------------	---	-------------	-----------------------------

CC for Field Log



# DAILY FIELD REPORT

PAGE 1

Project #: 168-038	Project Name: S <sup>B</sup> + O SAC	Date: 10-9-98	Day: Fri	Weather:
Client: MARK III		Client's Representative: Mike		
Contractor: MARK III		Other Persons Contacted: Alan		
Type of Work: Field welding		Location of Work: SAC		
FIELD ACTIVITIES:			Arrived:	Departed:

Arrived at site + Contacted Mike (MARK III) + found out what they were going to do while at site I observed the epoxy of five bolts 3 in line 4 installed into the CMU wall. Also two were installed with epoxy into the CMU wall north of line 1 between lines A+B.

I also observed the full pen welding of channel steel along line 1 in the south west portion of the building also (approximately) north of line 1 and along line 4 ~ 10 feet north of line 5. All running east west (channels) This completes all full pen welding for phase 3 as per plans + details. All welds were visually acceptable as per plans + specs. All welds observed were installed with an M.C.

EQUIPMENT ON SITE

Copy given to: Mike	Sample Pick-up: yes <input type="checkbox"/> no <input checked="" type="checkbox"/>	Total Time: 12 hrs.	Report by: Mike Grogan
------------------------	---	------------------------	---------------------------