

CITY OF SACRAMENTO

Permit No: 9800783

1231 I Street, Sacramento, CA 95814

Insp Area: 2

Site Address: 2505 RIVERSIDE BL SAC

Sub-Type: COM

Parcel No: 0090291020

Housing (Y/N): N

CONTRACTOR

DOLPHIN FIRE PROTECTION
PO BOX 99
ELVERTA CA 95626
Phone: 916-992-0299

OWNER

DAYTON HUDSON CORPORATION
MINNEAPOLIS MN 55440
Phone:

ARCHITECT

Phone:

Nature of Work: OH FIRE SPRINKLER EXTENSION

CONSTRUCTION LENDING AGENCY: I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name Lender's Address

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class C-16 License Number 475626 Date 3-4-98 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his or her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. B & PC for this reason:

Date Owner Signature

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

Date 3-4-98 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

X I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier FREMONT Policy Number WP 96585359-04

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 3-4-98 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

CITY OF SACRAMENTO  
 APPLICATION FOR BUILDING PERMIT  
 DEPARTMENT OF PLANNING AND DEVELOPMENT  
 BUILDING INSPECTION DIVISION

98-00783

RECEIVED

1231 I Street, Room 200  
 Sacramento, CA 95814  
 (916) 264-7619 FAX 264-7046

JAN 30 1998

P.C. # 5711  
 SUITE #  
 AREA # 2

ADDRESS 2525 RIVERSIDE BLVD

BUILDING DIVISION 009-0291-020

CONTACT

LICENSED CONTRACTOR Lic.#

NAME DELPHIN FIRE PROTECTION

NAME DELPHIN FIRE PROTECTION

ADDRESS 2525 RIVERSIDE

ADDRESS 2525 RIVERSIDE

ELVETA CA ZIP 95826

ELVETA CA ZIP 95826

PHONE 916-0299 FAX: (916) 990-0296

PHONE (916) 0299 FAX: ( ) -

ARCH./ENG.

OWNER

NAME

NAME TARGET STORES

ADDRESS

ADDRESS 2525 RIVERSIDE

ZIP

SITE ZIP

PHONE

PHONE ( ) - FAX ( ) -

WILL THE PERMITEE HAVE ANY EMPLOYEE'S ON THE JOBSITE?  YES  NO

NATURE OF WORK IN DETAIL: O.H. Fire Sprinkler Extension

D.B.A. Target  VALUATION 115950/115950  
BELOW THIS LINE FOR BLDG. DEPT. USE ONLY

FLOOD STATUS Cost  S.C.A.T.

JOB DESCR. BLDG SHEL APT TH( ) REM( ) SW FIRE ADD OTH

INSP. DISCIPLINES  BLDG  MECH  PLUMB  ELEC  SITE  FIRE

# OF STORIES	AREA 1ST FL.	TOTAL AREA	OCCUP. GROUP	CONST. TYPE	FIRE SPRINK.	FIRE ALARM	FED CODE	VIO. FILE
	12000	12000	M	YN	(Y) N	(Y) N	18	OK
B	L	P	M	E	(F) ETC.	S	(D)	R

COMMENTS:

1.30.98

Worker's Comp Policy # 16756555  
 Company FFA/ILAC  
 Exp. Date 1/31/98

(REGIONAL SAN FEES? Y/N) (HEALTH DEPT? Y/N)

DEPARTMENT OF UTILITIES, CITY OF SACRAMENTO

CONTRACT NUMBER: PATRICIA AMMOT OF PHONE NO: 998-0299 FAX NO: 998-0296

COMPANY: DOLPHIN FIRE PROT CELL PHONE NO:

COMPANY ADDRESS: P.O. BOX 99, SAVERIO, CA. STREET ADDRESS OF TEST: 2525 RIVERSIDE

PURPOSE OF TEST: FIRE SPRINKLER HYD. CALCS

- The undersigned agrees to the following terms and conditions:
- (1) The cover address shown above is correct.
  - (2) Water supply data is developed from several sources of information which may include water supply test data, pipe network computer models, and continuous pressure recording stations. The design water supply data given below is to be used for design purposes.
  - (3) Although the water supply data reported herein is believed to be correct, the City makes no warranty, guarantee, certification or other representation of any kind that such data is accurate or correct, or that the pressures and/or flow rates reported herein can or will be maintained. The undersigned agrees that the City, its officers and employees shall not be liable for any damages of any kind resulting from the use of or reliance upon the water supply data reported herein by the undersigned or by any third party.
  - (4) If the undersigned desires to witness the water supply test performed by the City, please check the box below:
    - I want to witness this water supply test, which will be scheduled at the convenience of the Department of Utilities.
    - If the undersigned desires to have a licensed engineer, at the undersigned's sole expense, to witness and certify the water supply test performed by the City, please check the box below:
      - At my expense, I will arrange for a licensed engineer to witness and certify this water supply test, which will be scheduled at the convenience of the Department of Utilities.

Print Name: PATRICIA AMMOT Signature: Patricia Ammot Date: 1-5-98

Used Test # 97-0131

ENGINEERING REQUEST DATE: TEST NUMBER:

FIELD SCHEDULE NO: 97-0131 Used

SCHEDULED DATE OF TEST:	SCHEDULED TIME OF TEST:	DATE OF TEST:	TIME OF TEST:
		<u>11-24-97</u>	

MAP NUMBER: WATER MAIN SIZE:

TEST CONDUCTED BY: COLLETTI, STOKLINE, LOPEZ

RESIDUAL	HYDRANT NO.	MAP PAGE	STATIC PRESS. (PSI)	RESIDUAL PRESS. (PSI)	PISTON PRESS. (PSI)	OUTLET DIA. (IN.)	COEFFICIENT		CALC. FLOW @ PRESS. (GPM)	TOTAL FLOW (GPM)	FLOW @ 20 PSI (GPM)
							C <sub>1</sub>	C <sub>2</sub>			
FLOWED											
FLOWED	<u>38</u>	<u>25</u>	<u>48</u>	<u>23</u>							
FLOWED	<u>39</u>	<u>25</u>			<u>10</u>	<u>4.5</u>	<u>0.90</u>	<u>0.75</u>	<u>1427</u>		
FLOWED	<u>76</u>	<u>23</u>			<u>14</u>	<u>4.5</u>	<u>0.90</u>	<u>0.75</u>	<u>1688</u>	<u>3115</u>	
FLOWED											

$$Q = 29.83 C_1 C_2 D^{5.21} \sqrt{P_{STAT} - P_{RES}}$$

$$Q_{80} = Q \left( \frac{P_{STAT} - 20}{P_{STAT} - P_{RES}} \right)^{0.54}$$

$$Q_{80} = 3115 \left( \frac{48 - 20}{48 - 23} \right)^{0.54} = 3312$$

SCAFFOLD PRESS.	COEFF.	DESIGN (I)
<u>48</u> PSI		<u>45</u> PSI
RESIDUAL PRESS.	<u>23</u> PSI	<u>20</u> PSI
FLOW @ RESIDUAL PRESS.	<u>3100</u> GPM	<u>3100</u> GPM
FLOW @ 20 PSI	<u>3300</u> GPM	<u>3100</u> GPM
RESIDUAL HYDRANT NO.	<u>38</u>	
RESIDUAL HYDRANT DIA.	<u>6.5</u>	

1. The Design Flow Rate, Design Pressure, and other data on this form are to be used for design purposes only.

# MEMORANDUM

*Sacramento Fire Department*

To: BUILDING DEPARTMENT

Date: 11-18-98

From: Gordon Duncan,  
Fire Marshal

Subject: **FIRE SYSTEM INSPECTION**

A final inspection of the newly installed fire system at:

2505 Riverside

has been conducted by Inspector K. Lee

on 11-16-98.

98-00783-C  
Permit Number

12,000  
Square Footage

Fire Spr Ext  
Type Inspection

The system is acceptable by this department.

R Woodman  
By: Ross L. Woodman,  
Fire Prevention Officer II

TI-185 + 98-25  
F. D. Reference Number