

CITY OF SACRAMENTO

1231 I Street, Sacramento, CA 95814

Permit No: 0503933

Insp Area: 3

Thos Bros: 298G7

Site Address: 8815 FOLSOM BL SAC

Parcel No: 078-0022-032

Sub-Type: REM

Housing (Y/N): N

CONTRACTOR

A.P. THOMAS
8680 GREENBACK LN.
ORANGEVALE CA. #220 95662

OWNER

CALIFORNIA COMMUNITY CREDIT UNI
3313 WISSEMANN DR
SACRAMENTO, CA 95826

ARCHITECT

BRESCHI & PATTERSON INC
914 DOUGLAS BLVD
ROSEVILLE CA 95678

Nature of Work: 4854 SF TI,demo exist walls, new metal stud framing , drywall, bath reconfig, new hvac, site improv for ada

CONSTRUCTION LENDING AGENCY : I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name Lender's Address

LICENSED CONTRACTORS DECLARATION: I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class License Number 637869 Date 5-9-05 Contractor Signature [Signature]

OWNER-BUILDER DECLARATION: I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. B & PC for this reason:

Date Owner Signature

IN ISSUING THIS BUILDING PERMIT, the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of a any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the abovementioned property for inspection purposes.

Date 5-9-05 Applicant/Agent Signature [Signature]

WORKER'S COMPENSATION DECLARATION: I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier STATE COMPENSATION INS FUND Policy Number 160488300 Exp Date 11/29/2005

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 5-9-05 Applicant Signature [Signature]

WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.

PAID CITY OF SACRAMENTO MAY 09 2005 BUILDING PERMIT

LICENSE NO. 698122

HELPING TO SOLVE YOUR ENERGY NEEDS TODAY & TOMORROW

DATE: 8/1/05  
 PAGE: 1 OF 4

Project: California Community Credit Union  
 System: Lennox Split Gas/Elect. Honeywell T-stats

**AIR DISTRIBUTION TEST SHEET**

Terminal Number	Room Number	Terminal		Factor	Design		Test - FPM or CFM			Final FPM	CFM	
		Type	Size		FPM	CFM	Test 1	Test 2	Test 3		COOL	HEAT
<u>AHU#1</u>												
1			14x14		500	531	499	467			519	
2			14x14		500	509	518	502			522	
3			12x12		300	339	493	460			323	
4			12x12		240	446	417	380			249	
<u>Return</u>												
1			24x24		920	1075	975	X			944	
2			↓		280	377	341	↓			306	
3			↓		220	341	315	X			240	

Remarks: OSA Damper set @ 125 CFM



9276 BEATTY DRIVE  
 SACRAMENTO, CA 95826-9707  
 PHONE 916-361-1799  
 FAX 916-361-1796  
 CONTRACTOR'S LICENSE# 698122

LICENSE NO. 698122

HELPING TO SOLVE YOUR ENERGY NEEDS TODAY & TOMORROW


DATE: 8/1/05  
 PAGE: 2 OF 4

Project: Cal. Community Credit Union  
 System:

AIR DISTRIBUTION TEST SHEET

Terminal Number	Room Number	Terminal		Factor	Design		Test - FPM or CFM			Final FPM	CFM	
		Type	Size		FPM	CFM	Test 1	Test 2	Test 3		COOL	HEAT
<u>AHU#2</u>												
1		1444			450	535	514	482		439		
2		1444			450	312	324	411		444		
3		1242			300	371	332	324		324		
4		1242			400	449	412	409		409		
5		1242			400	496	464	439		419		
<u>Return</u>												
1		2242			860	795	536	700		845		
2		↓			380	336	246	319		297		
3		↓			720	844	613	797		745		

Remarks: OSA Dampers Set @ 140 CFM



9276 BEATTY DRIVE  
 SACRAMENTO, CA 95826-9707  
 PHONE 916-361-1789  
 FAX 916-361-1796  
 CONTRACTOR'S LICENSE# 698122

LICENSE NO. 698122

HELPING TO SOLVE YOUR ENERGY NEEDS TODAY & TOMORROW

DATE: 8/1/05  
 PAGE: 3 OF 4

Project: Cal Comm. Credit Clinic  
 System:

AIR DISTRIBUTION TEST SHEET

Terminal Number	Room Number	Terminal Type	Terminal Size	Factor	Design		Test - FPM or CFM			Final FPM	CFM	
					FPM	CFM	Test 1	Test 2	Test 3		COOL	HEAT
AHU#3												
1			14x14		500	423	381	592		501		
2			12x12		320	355	254	498		307		
3			12x12		300	267	164	241		276		
4			12x12		350	267	323	383		341		
5			14x14		530	423	381	590		499		
Return												
1			8x8		480	506	486	*		495		
2			↓		300	338	376	↓		306		
3			↓		260	267	269	↓		270		
4			↓		330	375	334	↓		345		
5			↓		440	455	401	↓		499		

Remarks: OSA Dampers Set @ 145 CFM

LICENSE NO. 698122

HELPING TO SOLVE YOUR ENERGY NEEDS TODAY & TOMORROW

DATE: 8/1/05

PAGE: 4 OF 4

Project System

Cal. Comm. Credit Union

**AIR DISTRIBUTION TEST SHEET**

Terminal Number	Room Number	Terminal Type	Terminal Size	Factor	Design		Test - FPM or CFM			Final FPM	CFM	
					FPM	CFM	Test 1	Test 2	Test 3		COOL	HEAT
<b>AHU#4</b>												
1			14x14		470	487	419	470		475		
2			12x12		250	175	356	269		261		
3			12x12		250	435	356	271		262		
4			12x12		205	382	282	202		204		
5			8x8		50	82	72	96		66		
6			10x10		150	135	118	159		161		
7			12x12		250	286	239	313		277		
8			8x8		55	69	56	75		71		
9			8x8		100	72	61	78		101		
10			12x12		220	204	183	237		231		
<b>Return</b>												
1			20x22		555	760	686	*		570		
2					130	201	186			145		
3					35	105	96			45		
4					80	80	66			87		
5					146	329	106			195		
6					600	306	509	*		605		

Remarks

CSA Dampers Set @ 425