

**CONSTRUCTION LENDING AGENCY**

I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ.C).

Lenders Name \_\_\_\_\_

Lenders Address \_\_\_\_\_

**LICENSED CONTRACTORS DECLARATION**

I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class \_\_\_\_\_ Lic. Number \_\_\_\_\_

Date \_\_\_\_\_ Contractor \_\_\_\_\_  
(Signature)

**OWNER - BUILDER DECLARATION**

I hereby affirm under penalty of perjury that I am exempt from the Contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: Any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00):

I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his or her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he or she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & P C for this reason \_\_\_\_\_

Date \_\_\_\_\_ Owner \_\_\_\_\_  
(Signature)

In issuing this building permit, the applicant represents, and the City relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and hereby authorize representative of this city to enter upon the abovementioned property for inspection purposes.

Date July 3, 1997 Signature of Applicant or Agent Stephen Sheppard

BUILDING SITE ADDRESS

4141 Power Inn Rd.

SUITE

INSP. AREA

4-C

ASSESSOR PARCEL NO.

061-0061-045-0000

COMMUNITY PLAN NO.

PLAN CHECK NO.

5134CL

NAME OF APPLICANT		ADDRESS	ZIP CODE	PHONE NO.
LICENSED CONTRACTOR		3195 Park Rd. #C		
Frontline Technologies		Benicia, CA	94510	(707) 747-6251
PROPERTY OWNER				
Jackson Prop.		5665 Power Inn Rd.	95824	
ARCH. ENGR.				
		LICENSE NO.		

NO. OF STORIES	NO. OF ROOMS	ROOF COVERING	AREA 1ST FLOOR	TOTAL AREA	GARAGE AREA	PATIO AREA	USE ZONE	STREET WIDTH

THIS PERMIT IS FOR:  BUILDING  MECHANICAL  PLUMBING  ELECTRICAL  SITE  FIRE OCCUP. GROUP

NATURE OF WORK IN DETAIL  
install 120 volt circuit to fuel pump motor 1/3 hp 5 amp 120 volt from existing panel-B spare 20 a circuit breaker. DBA: Front Line

FLOOD STATUS (Cost) SPECIAL CONDITIONS ATTACHMENTS: IIIN

CITY OF SACRAMENTO PERMIT SERVICES BUILDING INSPECTION DIVISION 264-7619

VALUATION \$ 6,680.00

ISSUED BY: Kikashima

DATE ISSUED 7/3/97

BUILDING PERMIT FEE \$ 233.00

PLAN CHECK/PROF FEE \$ paid

S.M.I. FEE \$

CONST. EXCISE TAX \$

CITY BUS LICENSE \$ 2.80

TECH. FEE \$ 16.96

WATER DEV. FEE \$

CITY SEWER DEV. FEE \$

REG. SEWER FEE \$

RESIDENTIAL CONST. TAX \$

TOTAL FEES \$ 252.76

THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK AUTHORIZED IS NOT COMMENCED WITHIN 180 DAYS.

CITY OF SACRAMENTO  
 APPLICATION FOR BUILDING PERMIT  
 DEPARTMENT OF PLANNING AND DEVELOPMENT  
 BUILDING INSPECTION DIVISION

1231 I Street, Room 200  
 Sacramento, CA 95814  
 (916) 264-7619 FAX 264-7046

P.C. # 5134

ADDRESS 4141 Power Inn Road.

SUITE # \_\_\_\_\_

PARCEL # 061 0061 045

AREA # 4C

CONTACT

LICENSED CONTRACTOR

NAME \_\_\_\_\_

NAME Frontline Technologies

ADDRESS \_\_\_\_\_

ADDRESS 3195 Park Road. Suite C

ZIP \_\_\_\_\_

Benicia CA ZIP 94510

PHONE \_\_\_\_\_ FAX: ( ) \_\_\_\_\_

PHONE (707)747-6251

ARCH./ENG.

OWNER/

NAME \_\_\_\_\_

NAME MV Transportation Jackson Prop

ADDRESS \_\_\_\_\_

ADDRESS 4141 Power Inn Road. 5665 Power Inn Rd

ZIP \_\_\_\_\_

Sacramento CA ZIP 95824

PHONE \_\_\_\_\_

PHONE (916)456-8045

WILL THE PERMITEE HAVE ANY EMPLOYEE'S ON THE JOBSITE?  YES  NO

NATURE OF WORK IN DETAIL: Install 120volt circuit to fuel pump motor 1/3 HP 5amp 120nolt from existing panel-B spare

20a circuit breaker.

D.B.A. Front Line

VALUATION \$ 6,680.00

BELOW THIS LINE FOR BLDG. DEPT. USE ONLY

FLOOD STATUS \_\_\_\_\_

S.C.A.T. \_\_\_\_\_

JOB DESCR. BLDG SHEL APT TI( ) REM(1) SW FIRE ADD OTH

INSP. DISCIPLINES  BLDG  MECH  PLUMB  ELEC  SITE  FIRE

# OF STORIES	AREA 1ST FL.	TOTAL AREA	USE ZONE	OCCUP. GROUP	CONST. TYPE	FIRE SPRINK.	FED CODE	VIO. FILE
				<u>RM</u>	<u>III</u>	<u>?</u>	<u>18</u>	<u>VH</u>
<u>B</u>	<u>L</u>	<u>P</u>	<u>M</u>	<u>E</u>	<u>F</u>	<u>S</u>	<u>D</u>	<u>R</u>
<u>3</u>	<u>13</u>			<u>13</u>	<u>3</u>		<u>DF</u>	
<u>4</u>	<u>4</u>			<u>DM</u>	<u>5/23/77</u>		<u>13</u>	

COMMENTS: \_\_\_\_\_

WICKETS CLUMP POLICY # COMPANY

CITY OF SACRAMENTO  
 APPLICATION FOR BUILDING PERMIT  
 DEPARTMENT OF PLANNING AND DEVELOPMENT  
 BUILDING INSPECTION DIVISION  
 1231 I Street, Room 200  
 Sacramento, CA 95814  
 (916) 264-7619 FAX 264-7046

P.C. # 5134  
 SUITE # \_\_\_\_\_  
 AREA # 4C

ADDRESS 4141 Power Inn Road.  
 PARCEL # 061 0061 045

CONTACT

LICENSED CONTRACTOR

NAME \_\_\_\_\_  
 ADDRESS \_\_\_\_\_  
 ZIP \_\_\_\_\_  
 PHONE \_\_\_\_\_ FAX: ( ) \_\_\_\_\_

NAME Frontline Technologies  
 ADDRESS 3195 Park Road. Suite C  
Benicia CA ZIP 94510  
 PHONE (707)747-6251

ARCH./ENG.

OWNER

NAME \_\_\_\_\_  
 ADDRESS \_\_\_\_\_  
 ZIP \_\_\_\_\_  
 PHONE \_\_\_\_\_

NAME MV Transportation Jackson Prop  
 ADDRESS 4141 Power Inn Road. 5665 Power  
Sacramento CA ZIP 95824 Inn Rd  
 PHONE (916)456-9645

WILL THE PERMITEE HAVE ANY EMPLOYEE'S ON THE JOBSITE?  YES  NO

NATURE OF WORK IN DETAIL: Install 120volt circuit to fuel pump  
motor 1/3 HP 5amp 120nolt from existing panel-B spare  
20a circuit breaker.

E-10

D.B.A. Front Line  VALUATION \$ 6,680.00  
BELOW THIS LINE FOR BLDG. DEPT. USE ONLY

FLOOD STATUS \_\_\_\_\_  S.C.A.T. \_\_\_\_\_

JOB DESCR. BLDG SHEL APT TI( ) REM(1) SW FIRE ADD OTH  
 INSP. DISCIPLINES  BLDG  MECH  PLUMB  ELEC  SITE  FIRE

# OF STORIES	AREA 1ST FL.	TOTAL AREA	USE ZONE	OCCUP. GROUP	CONST. TYPE	FIRE SPRINK.	FED CODE	VIO. FILE
				<u>EM</u>	<u>III N</u>	<u>?</u>	<u>18</u>	<u>VH</u>
<u>(B) 13</u>	<u>(L) 13</u>	<u>P</u>	<u>M</u>	<u>(E) 13</u>	<u>(F) 3</u>	<u>S</u>	<u>(D)</u>	<u>R</u>

COMMENTS: 5/23 5/23

WORKERS COMP Policy # \_\_\_\_\_  
 COMPANY \_\_\_\_\_  
 EXP. DATE \_\_\_\_\_

PERMIT NO.

97/10348C

CITY OF SACRAMENTO  
1221 - ST. ROOM 200  
BUILDING INSPECTIONS DIVISION

AREA NO.

3-C

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-5191 FOR REINSPECTION OF WORK

JOB LOCATION

4141 Power Inn Rd

INSPECTION REQUESTED

FINAL

THE UNDERSIGNED  BUILDING  PLUMBING  MECHANICAL  ELECTRICAL

INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

F 06973

① Conduit At Building  
corner to be properly  
secured with conduit  
straps

INSPECTOR

*J. Wilson*

DATE

8/28/97

BUILDING INSPECTIONS 264-5716

INSPECTOR'S COPY