

**CITY OF SACRAMENTO**

1231 I Street, Sacramento, CA 95814

Permit No: 0403788

Insp Area: 3

Thos Bros: 317G2

Site Address: 4020 39TH ST SAC

Parcel No: 020-0071-012

Sub-Type: RES

Housing (Y/N): N

CONTRACTOR

OWNER

ARCHITECT

ZAIN BHAMAN  
1828 TRIBUTE RD  
SACRAMENTO CA 95815

Nature of Work: ELECT PANEL C/O

**CONSTRUCTION LENDING AGENCY:** I hereby affirm under penalty of perjury that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3097, Civ. C).

Lender's Name \_\_\_\_\_ Lender's Address \_\_\_\_\_

**LICENSED CONTRACTORS DECLARATION:** I hereby affirm under penalty of perjury that I am licensed under provisions of Chapter 9 (commencing with section 7000) of Division 3 of the Business and Professions Code and my license is in full force and effect.

License Class \_\_\_\_\_ License Number \_\_\_\_\_ Date \_\_\_\_\_ Contractor Signature \_\_\_\_\_

**OWNER-BUILDER DECLARATION:** I hereby affirm under penalty of perjury that I am exempt from the contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code; any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he or she is licensed pursuant to the provisions of the Contractors License Law (Chapter 9 (commencing with Section 7000) of Division 8 of the Business and Professions Code) or that he or she is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than five hundred dollars (\$500.00);

I, as a owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professional Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or herself or through his/her own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he/she did not build or improve for the purpose of sale.)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code: The Contractors License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractors License Law).

I am exempt under Sec. \_\_\_\_\_ B & PC for this reason: \_\_\_\_\_

Date 3/15/04 Owner Signature [Signature]

**IN ISSUING THIS BUILDING PERMIT,** the applicant represents, and the city relies on the representation of the applicant, that the applicant verified all measurements and locations shown on the application or accompanying drawings and that the improvement to be constructed does not violate any law or private agreement relating to permissible or prohibited locations for such improvements. This building permit does not authorize any illegal location of any improvement or the violation of any private agreement relating to location of improvements.

I certify that I have read this application and state that all information is correct. I agree to comply with all city and county ordinances and state laws relating to building construction and herby authorize representative(s) of this city to enter upon the above-mentioned property for inspection purposes.

Date 3/15/04 Applicant/Agent Signature [Signature]

**WORKER'S COMPENSATION DECLARATION:** I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for workers' compensation as provided for by Section 3700 of the Labor Code, for the performance of work for which the permit is issued.

I have and will maintain workers' compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My workers' compensation insurance carrier and policy number are:

Carrier \_\_\_\_\_ Policy Number \_\_\_\_\_ Exp Date \_\_\_\_\_

(This section need not be completed if the permit is for \$100 or less) I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers' compensation laws of California and agree that if I should become subject to the workers' compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

Date 3/15/04 Applicant Signature [Signature]

**WARNING: FAILURE TO SECURE WORKER'S COMPENSATION COVERAGE IS UNLAWFUL AND SHALL SUBJECT AN EMPLOYER TO CRIMINAL PENALTIES AND CIVIL FINES UP TO ONE HUNDRED THOUSAND DOLLARS (\$100,000) IN ADDITION TO THE COST OF COMPENSATION, DAMAGES AS PROVIDED FOR IN SECTION 3706 OF THE LABOR CODE, INTEREST AND ATTORNEY'S FEE.**

**THIS PERMIT SHALL EXPIRE BY LIMITATION IF WORK IS NOT COMMENCED WITHIN 180 DAYS.**

0403788

3

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-7622 FOR REINSPECTION OF WORK.

JOB LOCATION 4020 37th St

INSPECTION REQUESTED Service change lot 2

THE UNDERSIGNED  BUILDING  PLUMBING  MECHANICAL  ELECTRICAL  
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

1. Min Meter Height is 48" to center
2. Can not Feed second Meter from breaker out of Main Service
3. Provide working clearance and access to panels
4. Provide grounding electrode system for services.
5. Bond water within 5' of entering building
6. Bond gas piping system
7. Support service riser conductor 36" from panel & at weatherhead

INSPECTOR Mark Berg DATE 4/2/04

BUILDING INSPECTIONS 808-5716

INSPECTOR'S COPY

PERMIT NO.  
0403288

CITY OF SACRAMENTO  
2101 ARENA BLVD, #200  
BUILDING INSPECTIONS DIVISION

AREA NO.  
3

WHEN CORRECTIONS HAVE BEEN MADE, CALL 264-7622 FOR REINSPECTION OF WORK.

JOB LOCATION 4020 39th

INSPECTION REQUESTED Service change 362

THE UNDERSIGNED  BUILDING  PLUMBING  MECHANICAL  ELECTRICAL  
INSPECTOR THIS DAY INSPECTED THIS STRUCTURE FOR THE REQUESTED INSPECTION AND FOUND THE FOLLOWING VIOLATIONS OF CITY AND/OR STATE LAWS GOVERNING SAME:

8. Provide proof of Inspection or permit for new Hvac system
9. Install N-M cable connectors where N-M cable enters panels
10. Provide inspection of all new wiring inside
11. Provide A.F.C.T protection for new wiring run to bedrooms receptacles
12. Do not splice bare grounds to neutral conductors
13. Incomplete Inspection

INSPECTOR Marc Ruedy DATE 4/2/04

BUILDING INSPECTIONS 808-5716

INSPECTOR'S COPY