

**BUILDING DIVISION—BUILDING INSPECTOR'S REPORT CARD**

**TYPE VII BUILDINGS**

<b>PERMIT NO.</b> <i>2837</i>	<b>LOCATION</b> <i>3731 X.</i>		
<b>DATE</b> <i>10-13-28</i>	<b>PURPOSE</b> <i>Garage, Fire Lane</i>	<b>ROOMS</b>	<b>APTS.</b>
<b>FILED</b> JUN 13 1928 SACRAMENTO BUILDING DIVISION	<b>OWNER</b> <i>Charles Hartung</i>	<b>PHONE</b>	
	<b>ARCHT</b>		
<b>CONTR</b> <i>D W Abramson</i>			
<b>DATA</b>	<b>STORIES</b> <i>Two -</i>	<b>SIZE</b>	

FOUNDATION	STORY	BSMT	1	2	3	ROOF	Chimneys	Cement Tests
Ex Wall	Jolts							
	Beams and Girders						Fire Place	
Int Wall	Studs and Columns						Gas Water Heater	
	Bridging Fire Stops						Heater Closet	
Piers	Fire Escape Stand Pipes						Furnace	Window Courts
	Metal Lath						Boiler Room	
	Stairs						Elevator Shaft	

DATE

CONDITION OF WORK—REMARKS

5/15/24 2<sup>nd</sup> Insp. PARTIAL FIRE LOSS. All burned  
 Timbers removed. Heater in closet to be  
 removed to porch and properly vented to Campbell  
 7/6/24 2<sup>nd</sup> Insp. Balance of Frame including new  
 Brick Fireplace Chimney on ext. OK. W. Campbell

COMPLETED  
 AND O. K.

INSPECTOR